

# **Feasibility Study of Economics and Performance of a Hydroelectric Installation at the Jeddo Mine Drainage Tunnel**

**A Study Prepared in Partnership with the Environmental Protection Agency for the RE-Powering America's Land Initiative: Siting Renewable Energy on Potentially Contaminated Land and Mine Sites**

Joseph Owen Roberts, Robi Robichaud, and Gail Mosey

Prepared under Task No. WFD3.1000

## Contents

Executive Summary.....	3
Hydro System Performance Including Job Creation Estimates.....	4
List of Figures .....	5
List of Tables .....	5
Introduction .....	6
Study Location and Background .....	6
Proposed Location .....	7
Hydroelectric Design Parameters .....	9
Hydroelectric Systems.....	10
Hydroelectric Resource Definition .....	13
Hydro Resource Verification through Correlation .....	17
Economics and Performance .....	18
Electricity Generation .....	18
Hydro System Performance Including Job Creation Estimates.....	19
Applicable Policy .....	19
Applicable State and Local Grants and Incentives.....	22
Geothermal Heat Pump System Design Considerations.....	22
Geothermal Heat Pump System Economics .....	23
Summary and Conclusions.....	25
Hydro System Performance Including Job Creation Estimates.....	25
Appendix A: Drums Elementary Electricity Bills.....	27
Appendix B: Conceptual Dam Design.....	28
Appendix C: Crossflow Turbine Information.....	29
Appendix D: Kaplan Turbine Information .....	30
Appendix E: Tabular Flow Duration Curve .....	31
Appendix F: Project Cost Sheet.....	32
Appendix G: RETScreen Results .....	34
Appendix H: Geothermal Primer for Water Source Applications .....	36
Open Loop Systems.....	37
Heat Pumps.....	38
Appendix I: Geothermal Heat Pump RETScreen Model Results .....	40

## Executive Summary

The U.S. Environmental Protection Agency (EPA), in accordance with the RE-Powering America's Land initiative, selected the Jeddo Tunnel Discharge site for a feasibility study of renewable energy potential<sup>1</sup>. Citizens of the area, city planners, and site managers are interested in redevelopment uses for this resource as remediation costs are estimated at \$15 million over the next 20 years<sup>2</sup> for a passive treatment system. The purpose of this report is to assess technical and economic viability of the site for hydroelectric and geothermal energy production. In addition, the report outlines financing options that could assist in the implementation of a system.

The site was found to be constructible and no large issues were raised from the turbine manufacturer or dam designer as to possible construction or maintenance issues. There may be environmental issues associated with the construction of a small water retention dam just below the tunnel outlet, but relative to the environmental impacts already affecting the immediate and larger Jeddo Basin drainage, it appears the overall impacts of this project relative to benefits would be benign.

The economics of the potential systems were analyzed using an electric rate of \$0.10/kWh<sup>3</sup>, assuming the power could be wheeled the short distance to local off takers such as the local Elementary school and wastewater treatment plant or be net metered to either facility. Table 1: Hydro System Performance Including Job Creation Estimates summarizes the system performance, economics, and job creation potential of modeled systems at the Jeddo discharge. Calculations for this analysis assume the 30% cash grant in lieu of the federal tax credit incentive, per Treasury Bill Section 1603<sup>4</sup>, would be captured for the system. This is an important point that merits further investigation, preferably by a lawyer/legal representative, due to the fact that 'new' hydroelectric facilities do not qualify for this cash grant. However, the project appears to meet the intent of the Section 1603 under the definition of a 'hydrokinetic facility'.

The results in Table 1 below show the impacts on the simple payback with and without the Treasury Bill cash grant. As shown, the up-front savings afforded by the cash grant positively impact simple payback of the project.

Next steps should include the clarification of whether or not this facility can meet the definition of 'hydrokinetic facility'<sup>5</sup> as well as the exploration of virtual net metering policy in the area. Given the nature of the project and its benefits to both the community and the environment, efforts should be made to pursue other grants and low interest loans that could increase the financial viability of the project. Also, further investigation of the optimization of the height of the dam and verification of the annual flow characteristics, which are contingent upon planned remediation within the drainage basin, should be undertaken.

---

<sup>1</sup> [http://www.epa.gov/renewableenergyland/docs/develop\\_potential/drums.pdf](http://www.epa.gov/renewableenergyland/docs/develop_potential/drums.pdf)

<sup>2</sup> Hewitt, Michael (2006, October) "Jeddo Tunnel Abandoned Mine Drainage Passive vs. Active Treatment Cost Estimates" EPCAMR; Eastern Pennsylvania Coalition of for Abandoned Mine Reclamation

<sup>3</sup> Appendix A: Drums Elementary Electricity Bills

<sup>4</sup> <http://www.treasury.gov/initiatives/recovery/Documents/guidance.pdf>

<sup>5</sup> <http://www.treasury.gov/initiatives/recovery/Documents/guidance.pdf> pg. 13-14

**Table 1: Hydro System Performance Including Job Creation Estimates<sup>6</sup>**

Hydro System Performance Including Job Creation Estimates								
System Size (kW)	Turbine Type	Turbine Design Flow (m <sup>3</sup> /sec)	Annual Output (kWh/yr)	System Cost	Energy Production Cost (\$/kWh)	Simple Payback Period (years)	Jobs Created (construction)	Cash Grant Utilization
247	Kaplan	4.7	1,162,453	\$2,014,233	0.0796	21.5	22.4	No
247	Kaplan	4.7	1,162,453	\$2,014,233	0.0796	17.4	22.4	Yes
405	Crossflow	5.8	1,029,433	\$2,063,516	0.0913	21.3	22.9	Yes

This project poses a great opportunity to produce carbon free energy from a source that is otherwise simply a pollutant. The educational value this facility could be used to deliver, about energy, the coal industry and its history, environmental awareness of the local watersheds, etc, is not readily quantifiable but, should be highly considered.

<sup>6</sup> Estimates assume an inflation rate of 1.2%, discount rate of 3%, utilization of the 30% Cash grant in lieu of tax credit, 80% debt ratio, 50 year project life, a 6% interest rate and 30 year note term, 1.2% energy escalation rate, and a O&M cost of \$35,000/year. Long term job-years are total jobs for the 50 year design life of the project at the aforementioned O&M cost which averages 0.39 jobs per year.

## List of Figures

Figure 1: Jeddo Basin Drainage Are.....	8
Figure 2: Proposed Dam Plan View.....	9
Figure 3: Turbine Application Chart.....	11
Figure 4: Crossflow Turbine.....	11
Figure 5: Kaplan Turbine.....	12
Figure 6: Locations of Data Collection Points.....	13
Figure 7: Area Precipitation Data Comparison.....	14
Figure 8: Flow Duration Curve for Water Year 1997.....	15
Figure 9: Wapwallopen Historical Streamflow Annual Averages .....	16
Figure 10 Scatterplot and Trendline Analysis of Jeddo Tunnel vs. Wapwallopen Stream Flow .	17
Figure 11: Possible Off Taker Locations .....	21
Figure 12: Potential Ground Source Energy Off Takers .....	23

## List of Tables

Table 1: Hydro System Performance Including Job Creation Estimates.....	4
Table 2: MCP Methods and Results .....	18
Table 3: Hydroelectric Losses .....	19
Table 4: Hydroelectric Turbine Performance Comparison.....	19
Table 5: Potential Ground Source Off Takers .....	24
Table 6: Hydro System Performance .....	25

## Introduction

The U.S. Environmental Protection Agency (EPA) launched the RE—Powering America’s Land: Siting Renewable Energy on Potentially Contaminated Land and Mine Sites initiative in September 2008. EPA and the U.S. Department of Energy’s (DOE) National Renewable Energy Laboratory (NREL) are collaborating on a number of projects to evaluate the feasibility of siting renewable energy (RE) projects on these potentially contaminated sites.

The EPA selected the Jeddo Tunnel Discharge site for a feasibility study of renewable energy potential. Citizens of the area, city planners, and site managers are interested in redevelopment uses for this resource as remediation costs are estimated at \$15 million over the next 20 years for a passive treatment system. The purpose of this report is to assess technical and economic viability of the site for hydroelectric and geothermal energy production. In addition, the report outlines financing options that could assist in the implementation of a system.

## Study Location and Background

The Jeddo Tunnel is a man-made water level drainage tunnel used to drain deep mines in the Eastern Middle Anthracite Field near Hazleton PA. Jeddo Tunnel A was completed in 1895 and this tunnel discharges into the Little Nescopeck Creek and drains four major coal basins; Big Black Creek, Little Black Creek, Cross Creek, and Hazleton. The tunnel was abandoned in 1955 following the collapse of the deep mining industry in the United States. The Jeddo Tunnel drains 32.24 square miles of hilly/mountainous terrain consisting of both active and abandoned mining sites, farmland, grazing land, forest land, rural residential homesteads and the city of Hazleton. Historical records<sup>7</sup> indicate discharges an average of 134 cubic meters per minute (cmm) into Little Nescopeck Creek, a High Quality Cold Water Fishery.

As precipitation filters through the active and abandoned mining sites, it picks up large quantities of Aluminum, Manganese, and Iron. The combination of the high levels of metals with the low pH of the water eliminates all animal life downstream of the confluence of the Jeddo discharge and the Little Nescopeck Creek and severely impairs the water quality in the Nescopeck River.<sup>8</sup> The levels of Aluminum, Manganese, and Iron are 9.9, 1.7 and 3.4 times higher than allowable levels of these metals in streams affected by Acid Mine Drainage (AMD) in the state of PA at the Jeddo tunnel discharge.<sup>9</sup> The Little Nescopeck Creek receives all the flow from the Jeddo Tunnel discharge, and the discharge from the tunnel is the primary source of pollution in the Little Nescopeck Creek Watershed. The tunnel discharge and Little Nescopeck Creek then join the Nescopeck Creek, which subsequently flows into the Susquehanna River around Berwick, PA.

There have been many studies aimed at mitigating the AMD pollution from the Jeddo Discharge but the least expensive proposed measures cost over \$15 million for 20 years of treatment.<sup>10</sup> As there seems to be no funding available at the levels needed for a treatment facility for the discharge from the Jeddo tunnel, the aim of this study is to explore the potential not to treat to AMD but to utilize the potential energy in the water flow to generate electricity. This project does not have the revenue generation capacity to pay for a complete AMD treatment measure but the revenue generated could be used to

---

<sup>7</sup> Ballaron, P., WATER BALANCE FOR THE JEDDO TUNNEL BASIN *Publication No. 208 August 1999*

<sup>8</sup> [http://www.epa.gov/reg3wapd/tmdl/pa\\_tmdl/LittleNescopeck/LittleNescopeckReport.pdf](http://www.epa.gov/reg3wapd/tmdl/pa_tmdl/LittleNescopeck/LittleNescopeckReport.pdf) pg. 28

<sup>9</sup> Dempsey, Brian; Mendinsky, Justin (2004, August) *DEP GG EMARR (10/1/03 to 6/30/04)* pg.6

<sup>10</sup> Hewitt, Michael (2006, October) *Jeddo Tunnel Abandoned Mine Drainage Passive vs. Active Treatment Cost Estimates* EPCAMR; Eastern Pennsylvania Coalition of for Abandoned Mine Reclamation

fund education or other worthwhile programs to help mitigate historical mining impacts thereby making beneficial use from a potential (but contaminated) resource.

## Proposed Location

The Jeddo Tunnel discharge is located near Drums, PA. Figure 1: Jeddo Basin Drainage Area shows the approximate boundaries of the 32.24 square miles of the Jeddo Basin. All of the precipitation in this area is either transpired, evaporated, or exists at the Jeddo Tunnel A discharge. There are still active surface Anthracite mining operations in several of the smaller areas and much of the area has been remediated to different extents. The basin contains many infiltration points created from mining operations, cave-ins, etc. which proportionally increases the fraction of precipitation that directly infiltrates the ground opposed to being collected in streams and natural ponds and basins. Remediation measures have been proposed which would reduce this fraction of direct infiltration and some of these measures are expected to be carried out in the near future. This will have some impact on the amount of water that will be transpired by plants or that will evaporate, but the current estimates from Pennsylvania Department of Environmental Protection (PADEP) show that this may possibly decrease average tunnel discharge several percent.<sup>11</sup> Peter Haentjens of Eastern Middle Anthracite Region for Recovery (EMARR) later clarified this point and gathered the following information from PA DEP.

“Hawbaker has an application to mine coal and aggregate out of the Monmouth Vane Mine east of the Hazleton Shaft that would involve about 150 acres. The reclamation plan would include catch basins and wetlands that would capture water that will percolate into the ground and the tunnel drainage. This would have little impact on tunnel discharge except for evaporation. There are other plans to restore surface flow to Black Creek and Hazle Creek after mining activities cease. There are significant problems associated with restoration of both of these creeks especially with blocking off existing sink holes. It will be our intention to convince DEP that using those sink holes to raise alkalinity makes more sense than plugging them. Even if DEP does proceed with current plans, the impact on Jeddo discharge would be fairly small. To reduce the discharge by 20% to 30% would require plugging all of the 22 sinks...”<sup>12</sup>

The land surrounding the tunnel discharge is currently owned by Pagnotti Enterprises, Inc. Pagnotti currently mines anthracite in the Jeddo Basin. The land use lease terms or long term land ownership have not been determined at this point in time. It is recommended that land ownership and use issues be resolved before the commitment of financial resources to a large project occurs.

Figure 1: Jeddo Basin Drainage Area shows the boundaries of the drainage area (outlined in red), the various tunnels constructed for drainage of the mines, the Jeddo discharge location, as well as current and past mining operations.

---

<sup>11</sup> Menghini, Michael PA DEP Phone conversation Oct 22, 2010

<sup>12</sup> Haentjens, Peter EMAR email Feb 18, 2011






Figure 1: Jeddo Basin Drainage Area



## Hydroelectric Design Parameters

Figure 2: Proposed Dam Plan View is meant to show only the location of the proposed dam, topography near the discharge, and relative sizes of the dam and streambed. Further detail can be seen in Appendix B: Conceptual Dam Design.




Figure 2: Proposed Dam Plan View

There were several proposed solutions in regards to generating electricity at the Jeddo Discharge. The proposed dam design is an earthen dam and the largest contingencies are based on the geology and geography of the exact location of the dam. Appendix B: Conceptual Dam Design details the approximate costs and technical feasibility of construction at the Jeddo Discharge. These cost estimates were used to model the lifecycle cost of the project.

The intake structure for the dam was recommended to be changed to one more easily cleaned by workers to be approximately 1 meter below the surface of the water and closer to the peak of the dam. This recommendation came from Canadian Hydro Components.

The dam design suggests that the top of the dam will be at an elevation of 1040 ft and the lower existing grade is at an elevation of 1017.7 ft. This gives a total potential of 22 ft of head. For turbine power

output calculations an assumed head of 21 feet was used due to water control level requirements, etc. This is still a somewhat conservative number as an additional foot of head would result in approximately 4.6% more average energy output. The topographic features suggest that moving the dam closer to the tunnel or simply increasing the height of the dam would easily gain 2 additional feet of head with minimal cost increases. It is possible to increase the net head up to an additional 10 feet with additional earth movement and additional cost. This may need to be investigated further as the capital costs of the turbine, site access, and electrical components will not change. This 2-10 ft increase in head would produce a 9-45% (respectively) increase in annual energy production, however due to the geography of the site the increase in cost will not be linear.

Other options include eliminating the dam and capping the tunnel to increase head pressure. However, this approach has a number of unknowns, such as the stability of the geotechnical conditions upstream of the tunnel, which make it a much riskier approach. For instance, capping the tunnel may result in leaching of accumulated contaminated water into the ground and spreading the flow of contaminants that had only been in the tunnel. However, significant amounts of “standing water” in the tunnel for long periods of time may actually strengthen tunnel walls but significant pressure on the walls may cause structural or water seepage issue. At this stage, capping the tunnel is not recommended.

## Hydroelectric Systems

Hydroelectric turbines convert the potential and or kinetic energy from water at a differential height to kinetic energy (rotation of the turbine and thus the generator) to electrical energy by means of a generator. The power potential of a turbine can be computed from Equation 1: Power Potential from a Hydroelectric Turbine where  $P$  is the power in Watts,  $\eta$  is the turbine efficiency (unitless ratio),  $\rho$  is the density of water ( $\text{kg/m}^3$ ),  $g$  is acceleration of gravity ( $9.81 \text{ m/s}^2$ ),  $h$  is head (m), and  $\dot{Q}$  is flow rate ( $\text{m}^3/\text{s}$ ).

### Equation 1: Power Potential from a Hydroelectric Turbine

$$P = \eta \cdot \rho \cdot g \cdot h \cdot \dot{Q}$$

Figure 3: Turbine Application Chart shows the applicable head pressures and flow rates of different turbine operating envelopes. The head pressures and flow rates within the yellow line polygon show the range of operating conditions for Francis turbines, and other colors correlate to that specific turbine technology as shown in their respectively colored polygons. Thus for the Jeddo site, which has a head of approximately 6.4m and a design flow of  $5.1 \text{ m}^3/\text{s}$ , applicable technologies are Kaplan and Crossflow turbines.




Figure 3: Turbine Application Chart<sup>13</sup>




Figure 4: Crossflow Turbine<sup>14</sup>

<sup>13</sup> [http://en.wikipedia.org/wiki/File:Water\\_Turbine\\_Chart.png](http://en.wikipedia.org/wiki/File:Water_Turbine_Chart.png)

The Crossflow turbine offers a simple design with lower peak efficiency but a much broader efficiency curve due to the sequential deployment of high velocity water onto varying areas of the turbine. Appendix C: Crossflow Turbine Information contains the efficiency curve and pricing data for a turbine sized specifically for the Jeddo Discharge Resource.




Figure 5: Kaplan Turbine<sup>15</sup>

Kaplan turbines considered for this application changes the pitch or angle of attack of the blades of the turbine to vary the amount of power extracted. Other Kaplan turbines have movable wicket gates surrounding the turbine which further increase the efficiency but add more cost and complexity and are typically not used for small hydro projects as the added cost cannot be recouped from increased output. These turbines can have a fairly wide range of flows that produce power but the efficiency drops at low flows.

Appendix D: Kaplan Turbine Information provides the estimated performance curve and cost data for a Kaplan turbine sized for the Jeddo resource.

---

<sup>14</sup> <http://www.hydroelectric.cz/hy-ossberger-en.php>

<sup>15</sup> [http://commons.wikimedia.org/wiki/File:S\\_vs\\_kaplan\\_schnitt\\_1\\_zoom.jpg](http://commons.wikimedia.org/wiki/File:S_vs_kaplan_schnitt_1_zoom.jpg)



## Hydroelectric Resource Definition

A water year is defined as the period of Oct1-Sep30 with the year being defined by the year that Sep30 falls in. Thus if the period ends Sep 30 1998 then this would be referred to water year 1998. All years in this section of the paper should be assumed to be water years.




Figure 6: Locations of Data Collection Points<sup>16</sup>

Several long term stream gauges and precipitation gauges were used to extrapolate the long term tunnel discharge flow. Figure 6: Locations of Data Collection Points shows the Jeddo basin as well as the USGS precipitation and stream gauges used to determine the average annual tunnel discharge. A study in 1999 by SRBC studied the water balance in the Jeddo basin to evaluate possible remediation measures to reduce the tunnel discharge.

This study found the base flow is 30-33 cubic feet per second natural ground water drainage during drought and summer months.<sup>17</sup> Selection of a hydroelectric turbine that still produces electrical energy at this low flow is critical as flows during the summer months can typically reach these levels and there seems to be no cost effective advantage to using a significantly larger turbine to capture more energy from the high flow periods.

<sup>16</sup> <http://www.google.com/earth/index.html>

<sup>17</sup> Ballaron, Ibid. p.19



Precipitation averaged about 49 inches per year in the area (based on data from Tamaqua reservoir) for the 66-year period from 1932 to 1998. A comparison of this average with precipitation in 1996, 1997, and 1998 indicates that, in 1996, precipitation in Hazleton exceeded the average by 11 percent. Precipitation was about average in 1997. For 1998, precipitation was 13 percent below average in the Jeddo Tunnel Basin.<sup>18</sup>

Thus, based on the historical data available to Ballaron, it appears that 1997 was an average precipitation year for the Jeddo basin area. Thus streamflow data from 1997 was assumed to be approximately average. There is some risk in this assumption due to the frequency distribution of rain events in that year which was followed by a drought year, but that type of hydrology probability analysis is typically associated with a much larger hydro project.




Figure 7: Area Precipitation Data Comparison

Figure 7: Area Precipitation Data Comparison shows the four main precipitation data sources for the Jeddo area. The observed data comes from the 1999 Ballaron report and all years are hydrological years. Ballaron used USGS site 368758 Tamaqua for long term precipitation estimation but this dataset only contains records from 1932 to 1998.

The assumptions above were then validated using the PRISM dataset which is arguably the most extensive compilation of precipitation data in the United States.

<sup>18</sup> Ballaron. Ibid. p.11

PRISM is a unique knowledge-based system that uses point measurements of precipitation, temperature, and other climatic factors to produce continuous, digital grid estimates of monthly, yearly, and event-based climatic parameters. Continuously updated, this unique analytical tool incorporates point data, a digital elevation model, and expert knowledge of complex climatic extremes, including rain shadows, coastal effects, and temperature inversions. PRISM data sets are recognized world-wide as the highest-quality spatial climate data sets currently available. PRISM is the USDA's official climatological data.<sup>19</sup>

The PRISM dataset estimates the annual average rainfall within the Jeddo Basin to be 49.28 inches per year between 1960 and 2009<sup>20</sup>. This estimate is consistent with Ballaron's suggestion that 1997 was approximately an average precipitation year.




Figure 8: Flow Duration Curve for Water Year 1997

Figure 12: Flow Duration Curve for Water Year 1997 shows the flow duration curve for the Jeddo tunnel discharge for the 1997 water year (10/1/1996-9/30/1997). This illustrates the baseflow with no records in 1997 being lower than 37 m<sup>3</sup>/min and a 5% exceedence flow of 45m<sup>3</sup>/min. Appendix E: Tabular Flow Duration Curve has this data in a tabular format for future use.

<sup>19</sup> <http://www.prism.oregonstate.edu/>

<sup>20</sup> [http://prismmap.nacse.org/nn/index.phtml?vartype=ppt&month=14&year0=1971\\_2000&year1=1971\\_2000](http://prismmap.nacse.org/nn/index.phtml?vartype=ppt&month=14&year0=1971_2000&year1=1971_2000)




Figure 9: Wapwallopen Historical Streamflow Annual Averages

Ballaron and others at the Pennsylvania Department of Environmental Protection (PA DEP) recommended using USGS stream gauge 01538000 Wapwallopen Creek stream gauge to attempt to correlate the historical stream flow data with tunnel outflow. Reportedly this is one of the most consistent and longest datasets available within the immediate Jeddo area for stream flow data. Figure 9: Wapwallopen Historical Streamflow Annual Averages shows that the annual average flow for the 1997 hydrological year was 4.3% above the annual average from 1970 through 2009. This is fairly consistent with Ballaron’s findings that 1997 was an average precipitation year for the Jeddo basin, but again this data is not within the Jeddo basin so there is some uncertainty in the degree of correlation.

Linear scaling of the resource with correlated precipitation data is not possible since some groundwater base flow exists, surface runoff fraction changes, and evapotranspiration changes. Surface runoff data taken for the 1999 Jeddo Water Balance showed a variation of 5 to 11% of total precipitation on a yearly basis was recorded as direct runoff.<sup>21</sup> Thus the fraction of precipitation that passes through the basin is not constant but averages 66.3% over the three year study of the water balance in the Jeddo Basin.

Surface remediation in the Jeddo Basin is planned but conversations with the PA DEP confirmed that the drainage area would not change, although some ponds may be created as part of this remediation. These shallow catchment basins could have two affects, one being they will increase evaporation, and

<sup>21</sup> Ballaron. Ibid. p.11

the other being they will act as a storage medium which will help regulate tunnel discharge. The DEP currently plans to reshape most of the basin and install shallow catchment basins. This storage of water on the surface should be minimal which minimizes evapotranspiration, however, there are plans to vegetate these basins which will increase transpiration. Thus, if the effective storage of the basin increases, the overall output from the hydroelectric facility could be significantly increased as the current modeling approach for the Jeddo drainage system ignores the storage that is present in mine pools. Further plans have been discussed to place a low-permeability material just below the surface which would reduce infiltration and tunnel output by 10-25 percent.<sup>22</sup> This decrease in tunnel output flow would be highly dependent on what drainage area the material is placed in and how extensive the material placement is.

### Hydro Resource Verification through Correlation

The stream flow data from the Wapwallopen Creek and Jeddo Discharge were compared via scatterplot, as shown in Figure 10 below, to determine the extent of their correlation given that they are in different watershed basins. An analysis technique known as Measure – Correlate – Predict (MCP) was undertaken with three different statistical approaches. Both Linear and Exponential Regression Analysis techniques were applied to the scatterplot with the resultant equations and correlation factors ( $R^2$ ) shown in the colored text boxes.




Figure 10 Scatterplot and Trendline Analysis of Jeddo Tunnel vs. Wapwallopen Stream Flow

A 3<sup>rd</sup> MCP technique, known as Variance Ratio Analysis was also investigated. The results of all three methods are shown in Table 2 below.

<sup>22</sup> Ballaron. Ibid. p.22

**Table 2: MCP Methods and Results**

<b>Measure Correlate Predict Methods and Results</b>			
<b>Method</b>	<b>Prediction Equation</b>	<b>Correlation Equation</b>	<b>R<sup>2</sup></b>
Linear	$(0.637 * \text{Wap flow}) + 32.35$	$y = 0.637x + 32.35$	$R^2 = 0.6505$
Exponential	$(2.9757 * \text{Wap flow})^{0.7371}$	$y = 0.775x^{1.0052}$	$R^2 = 0.7649$
Variance ratio	$(\text{Jeddo avg} - ((\text{Jeddo stdev} / \text{Wap stdev})) * \text{Wap avg}) + ((\text{Jeddo stdev} / \text{Wap stdev}) * \text{Wap flow})$	$y = 0.8065x + 15.098$	$R^2 = 0.6505$

Table 2 shows the prediction equations and R<sup>2</sup> values for these three MCP methods. The R<sup>2</sup> correlation factor provides an indication of the relative “goodness of fit” of the regression line to the data. The exponential regression equation results in the highest R<sup>2</sup> value and is used as the basis for Jeddo Tunnel flow predictions in subsequent economic modeling. This data was filtered for all values greater than 500 cubic feet per minute since the turbine outputs are constant above this flow rate.

Overall, all datasets within the site specific study period of 1996-1998 show the same trend with differing magnitudes of change. None of these methods accurately predict the tunnel outflow that occurs during/after significant precipitation events and its use for daily stream flow estimates is not recommended. However, the models perform reasonably well for longer time frames such as annual stream flow quantities and this is the basis of the economic modeling. If a hydroelectric project is deemed feasible, it is advised that further study into the number of rain events per year and the magnitude of these events be studied to ensure optimization of the equipment to be used in the hydroelectric system. This lack of daily predictability is due to the great complexity of a hydrologic system and the relatively large distance between the two drainage basins and the limitations of regression analysis equations for discrete event prediction. A true hydrologic study comparing these two drainage basins may improve the prediction reliability for the Jeddo Tunnel, though the current analysis may be sufficient for the type of hydroelectric project proposed.

## **Economics and Performance**

### **Electricity Generation**

While the lifetime of this project was modeled at 50 years, which is a typical design life for a hydroelectric project of this scale, historically it can be seen that the engineering practices still incorporated in hydroelectric generation produce projects with usable lives up to twice the design life.

Crossflow and single-regulated Kaplan turbines were considered for this application. Crossflow turbines require a gearbox and other moving parts to regulate the flow of the water through the turbine, whereas the Kaplan designs do not require a gearbox and have only limited moving parts in the turbine. Crossflow turbines also require much finer trash filtering systems as their runners are spaced much closer together and require more frequent cleanings of the intake and turbine runners. Kaplan turbines are also more efficient at their peak, but have a slightly higher capital cost. Since project size and economics speaks to the facility being unmanned on a daily basis, a higher reliability, lower maintenance turbine, such as the Kaplan, is recommended.



The economic models assume that a cash grant in lieu of the Investment Tax Credit (ITC) will be utilized to put some capital down to secure lower loan rates. The model assumes a 30 year loan at 6% interest rate with the full amount of the remainder of the cost of the project after the cash grant to be financed. Appendix F: Project Cost Sheet details the various costs for both a Kaplan and Crossflow turbine utilizing the proposed dam design.

The losses were modeled as appear in Table 3: Hydroelectric Losses.

**Table 3: Hydroelectric Losses**

Hydroelectric Generation Assumed Losses	
Turbine Hydraulic Losses (Included in power curves)	NA
Regular Maintenance (1.5 weeks a year)	3%
Electrical and Distribution	3%
Turbine Degradation and Other Hydraulic Losses	4%

Table 4: Hydroelectric Turbine Performance Comparison shows the energy production and associated economic results. Further details can be seen in Appendix G: RETScreen Results.

**Table 4: Hydroelectric Turbine Performance Comparison<sup>23</sup>**

Hydro System Performance Including Job Creation Estimates								
System Size (kW)	Turbine Type	Turbine Design Flow (m <sup>3</sup> /sec)	Annual Output (kWh/yr)	System Cost	Energy Production Cost (\$/kWh)	Simple Payback Period (years)	Jobs Created (construction)	Cash Grant Utilization
247	Kaplan	4.7	1,162,453	\$2,014,233	0.0796	21.5	22.4	No
247	Kaplan	4.7	1,162,453	\$2,014,233	0.0796	17.4	22.4	Yes
405	Crossflow	5.8	1,029,433	\$2,063,516	0.0913	21.3	22.9	Yes

## Applicable Policy

Current PA policy<sup>24</sup> allows virtual meter aggregation which enables a single account holder to essentially sum the meters within two miles of the generation source. It is unclear if the account holder must lease or own the land that the generation source is installed upon but the electrical account holder name must be the same. There have been examples of third parties installing PV systems at little or no cost to owners who have qualified for net metering because the contract with the PV equipment supplier requires the land owner to ‘operate’ or ‘maintain’ the PV system by cleaning the PV panels with some frequency. Thus this suggests that the equipment owner does not need to be the landowner, but the account holder must be the entity which has a load and generates the electricity as well as ‘operates’ or ‘maintains’ the system which could be as simple as writing an O & M contract with a 3<sup>rd</sup> party.

<sup>23</sup> Estimates assume an inflation rate of 1.2%, discount rate of 3%, utilization of the 30% Cash grant in lieu of tax credit, 80% debt ratio, 50 year project life, a 6% interest rate and 30 year note term, 1.2% energy escalation rate, and a O&M cost of \$35,000/year. Long term job-years are total jobs for the 50 year design life of the project at the aforementioned O&M cost which averages 0.39 jobs per year.

<sup>24</sup> [http://www.dsireusa.org/incentives/incentive.cfm?Incentive\\_Code=PA03R&re=1&ee=1](http://www.dsireusa.org/incentives/incentive.cfm?Incentive_Code=PA03R&re=1&ee=1)

Obviously, there would be excess generation with the current scenario since the school load average is approximately 90 kW and the average hydro generation is 150 kW.

More conventional options include having a third party lease the land, own and maintain the equipment, and sell the power and/or recs. This would allow that third party to take advantage of the Production Tax Credit (PTC) or Investment Tax Credit (ITC). The PTC is currently 1.1 cents per kWh for the first ten years of a qualified hydroelectric project which would amount to \$152,264 total over the first 10 years of the project whereas the cash grant in lieu of the tax credits<sup>25</sup> would provide an upfront cash grant of 30% of the installed cost of the project amounting to slightly over \$600,000.

While this project would not qualify as a hydroelectric facility for this cash grant (only incremental hydropower production projects to existing hydroelectric facilities are allowed), the facility would possibly qualify as a hydrokinetic facility due to the fact that the Jeddo tunnel was manmade.<sup>26</sup> However, there is specific language within this document explicitly prohibiting a dam or any impoundment for electrical production purposes. There is language that allows electrical production from diversionary structures with the specific exception of manmade structures. It seems that the intent of the bill is to not support the further damming of streams and rivers, but to encourage energy capture from irrigation and other manmade sources of water flow. Thus, the Jeddo Tunnel project appears aligned with the intent of this law but may not directly fit under the letter of the law. It may be worth pursuing legal assistance from EPA or other regulatory authority to support this project and present an appeal the Treasury. This project appears well aligned with the intent of the legislation and should be pursued from that perspective.

The local REC prices on average are at 0.365 cents per kWh for Tier 1<sup>27</sup> RECs, but this value may increase in the near future due to the aforementioned increase in PA state REC requirements. The price of energy that this third party would be able to sell at would be significantly less than the assumed \$0.10 used in the modeling.

The project was modeled assuming that the electricity could be “wheeled” to the local school and wastewater treatment plant at the rate that the school is currently being charged for its electricity. This would need to be a negotiated arrangement between the off takers and PPJ and the utility may want to charge a fee for wheeling the electricity from the point of interconnection to the respective loads. The project owner would need to register as a qualifying facility (QF), per the Public Utility Regulatory Policies Act of 1978 (PURPA)<sup>28</sup>, to be an electricity generator with the PA Public Utility Commission

---

<sup>25</sup> <http://www.treasury.gov/initiatives/recovery/Documents/guidance.pdf>

<sup>26</sup> <http://www.treasury.gov/initiatives/recovery/Documents/guidance.pdf> p. 13-14

<sup>27</sup> Tier 1 includes low impact hydroelectric generation, wind, biomass, and others. The prices for Tier 1 RECs from 2008-2009 ranged from \$0.5 to \$23/MWh. The demand for Tier 1 RECs is unknown with more energy suppliers joining the PJM interconnection (any supplier in the PJM interconnection can sell RECs towards the PA state RPS. The PA state RPS requirements for Tier 1 generation increase at a rate of 0.5% per year for the next 10 years, which represents a tripling of demand for Tier1 RECs in 10 years. Historical averages for REC costs have been higher than the most recent data, but due to the short history of the PA RPS and the fact that generators have 3 years to retain or sell their RECs, it is very hard to judge the future prices if RECS based on historical data. The compliance charge is currently \$45/MWh but this does not seem to be a large driver currently for REC prices. The hydro installation must also qualify as ‘low impact’ (<http://www.lowimpacthydro.org/>) but due to the current environmental damage that the project should qualify as low impact.

[http://www.puc.state.pa.us/electric/pdf/AEPS/AEPS\\_Ann\\_Rpt\\_2008-09.pdf](http://www.puc.state.pa.us/electric/pdf/AEPS/AEPS_Ann_Rpt_2008-09.pdf)

<sup>28</sup> Warwick, W.M., A Primer on Electric Utilities, Deregulation, and Restructuring of U.S. Electricity Markets, US Department of Energy, May 2002. <http://www1.eere.energy.gov/femp/pdfs/primer.pdf>

(PUC). The average output from the turbine is modeled at 158 kW which exceeds the school's annual average usage by ~89 kW. The wastewater treatment plant's load has been quoted at 100 kW or greater, but no documentation has been available to support this.

The project will require the upgrade or new installation of distribution level voltage lines (possibly between 10 and 14kv depending on the local utility voltage) for approximately 1850 ft where it could interconnect with existing three phase distribution lines. The power would then need to be wheeled 2200 ft to the wastewater treatment plant or 2500 feet to the local school. Figure 11: Possible Off Taker Locations shows the relative locations of the possible off takers to the Jeddo discharge.




Figure 11: Possible Off Taker Locations<sup>29</sup>

Electrical energy costs are projected to increase at a rate of 1.19% annually averaged from 2010 to 2039 by EIA<sup>30</sup> and this assumption was used in the economic modeling of the project. The discount rate and inflation were taken to be 3.0% and 0.9% respectively which are specified by NIST<sup>31</sup>.

The estimated cost from Rizzo and Associates was used to model the construction and engineering cost of the dam and installation of the turbine and powerhouse. The turbine cost and choice is still a major variable since the resource is not well defined in this study. The resource was assumed to be average in 1997 based on the recommendations of Ballaron due to the access to historical precipitation data within the basin. Slight differences in the penstock diameter may also play into the turbine selection due to different design flows which are inherent to the Kaplan and Crossflow turbines, so further optimization should be conducted in this area.

<sup>29</sup> <http://www.google.com/earth/index.html>

<sup>30</sup> <http://www.eia.doe.gov/>

<sup>31</sup> [http://www1.eere.energy.gov/femp/news/news\\_detail.html?news\\_id=15859](http://www1.eere.energy.gov/femp/news/news_detail.html?news_id=15859)

Operations and maintenance costs were estimated at \$35,000 annually which includes a service contract for annual maintenance from the turbine supplier and remote monitoring of the system. This cost estimate also includes a portion of revenue to be set aside in an escrow account, approximately \$10,000 annually, to be utilized in the instance of a major repair needed in the future. An annual land fee of \$10,000 was also included in the \$35,000 total. Spare parts were also included at a cost of \$50,000 up front cost to have an inventory of maintenance related parts to be retained to minimize downtime in the instance of a mechanical failure. Though it is expected that the Kaplan turbine will have lower O&M costs due to turbine design advantages for this site, there were no reliable cost figures available, so both turbines were modeled with the same O&M costs.

## Applicable State and Local Grants and Incentives

Many state and local grants and incentives exist that may provide some capital or rebates to the project to increase the financial viability of this project. The Database of State Incentives for Renewables and Efficiency for the state of PA<sup>32</sup> provides a listing of grants, incentives, and rebate programs available through local utilities and the state. The state of PA has a revolving loan program that has the potential to fully fund this project<sup>33</sup> and may offer lower a lower interest rate than was modeled. The state of PA also offers a small grant program that could pay for some of the site investigation<sup>34</sup> if the local school was willing to apply to achieve a LEED Silver rating for its building. The Sustainable Energy Fund Loan Program<sup>35</sup> applies to the PPL territory and may be utilized if a real educational aspect of the project could be realized. The Pennsylvania Energy Development Authority<sup>36</sup> also offered a large grant possibility through the American Reinvestment and Recovery Act but may have the potential to continue.

A further investigation of these loans and grants should be made as some of these possibilities could boost the economic viability of this project.

## Geothermal Heat Pump System Design Considerations

Per EPA's request, NREL investigated the potential for geothermal energy production at this site utilizing the water from the Jeddo Discharge. Since the flow of water from the tunnel has a component of its flow that is not affected by drought, this resource could be suitable for use as a heat sink and heat source for building space heating and cooling. The largest variable for these possible systems is that the stream temperatures through the seasons are unknown. Discussions with SRBC indicated that the aggregate water temperature would be made of components similar to the makeup of the flow of the water. Thus there is some base component of flow that is made up of ground water which constitutes approximately 0.9 cubic meters per second which should have a temperature approaching deep ground temperature. However, the shallow depth of the stream will be conducive to solar gain as the water exits the tunnel and makes its way to the point where the heat exchangers would be placed.

Appendix H: Geothermal Primer for Water Source Applications serves as an introduction to how these water source heat pumps operate and the factors that affect their performance and economic viability. Most ground or water source heat pump systems become economically viable at larger scales and where more expensive fuel sources for heating are used (such as electricity through air source heat

---

<sup>32</sup> [http://www.dsireusa.org/incentives/incentive.cfm?Incentive\\_Code=PA73F&re=1&ee=1](http://www.dsireusa.org/incentives/incentive.cfm?Incentive_Code=PA73F&re=1&ee=1)

<sup>33</sup> [http://www.dsireusa.org/incentives/incentive.cfm?Incentive\\_Code=PA73F&re=1&ee=1](http://www.dsireusa.org/incentives/incentive.cfm?Incentive_Code=PA73F&re=1&ee=1)

<sup>34</sup> [http://www.dsireusa.org/incentives/incentive.cfm?Incentive\\_Code=PA25F&re=1&ee=1](http://www.dsireusa.org/incentives/incentive.cfm?Incentive_Code=PA25F&re=1&ee=1)

<sup>35</sup> [http://www.dsireusa.org/incentives/incentive.cfm?Incentive\\_Code=PA08F&re=1&ee=1](http://www.dsireusa.org/incentives/incentive.cfm?Incentive_Code=PA08F&re=1&ee=1)

<sup>36</sup> [http://www.dsireusa.org/incentives/incentive.cfm?Incentive\\_Code=PA16F&re=1&ee=1](http://www.dsireusa.org/incentives/incentive.cfm?Incentive_Code=PA16F&re=1&ee=1)

pumps or direct radiation, as opposed to natural gas direct heating). The federal government offers incentives for high efficiency furnaces, heat pumps, and other HVAC components.<sup>37</sup> The state of PA also offers loans for geothermal heat pump installations at \$3/ft<sup>2</sup> up to \$5 million. The fund was allocated with \$25 million in January 2009, and it is unclear as to how much funding remains.<sup>38</sup> The PPL utility area also may have some applicable loan services that would reduce the cost of a geothermal heat pump installation.<sup>39</sup>

The most feasible geothermal heat pump system for buildings near the Jeddo Discharge would be a closed loop system which uses flat plate heat exchangers. The flow rate of the stream is such that heat added from any of the possible buildings will be insignificant relative to the large quantities of cool water continuously flowing by. The heat discharged from the heat exchangers is mixed rapidly with the moving river water so heat build-up in the water stream is relatively minor. Assuming a minimum flow of 0.9 cubic meters per second, a 130 ton air conditioning unit will only raise the temperature of the stream several tenths of one degree Celsius continuously at full cooling output. This temperature increase should be further studied to ensure this increase in temperature will not affect stream life at the confluence of the Little Nescopeck and the Jeddo Discharge, or downstream of this point.

## Geothermal Heat Pump System Economics

There are several potential off takers of this energy, namely an assisted living home, the local elementary school, and Keystone Job Corporation High School.




Figure 12: Potential Ground Source Energy Off Takers<sup>40</sup>

<sup>37</sup> [http://www.energystar.gov/index.cfm?c=tax\\_credits.tx\\_index](http://www.energystar.gov/index.cfm?c=tax_credits.tx_index)

<sup>38</sup> [http://www.dsireusa.org/incentives/incentive.cfm?Incentive\\_Code=PA40F&re=1&ee=1](http://www.dsireusa.org/incentives/incentive.cfm?Incentive_Code=PA40F&re=1&ee=1)

<sup>39</sup> [http://www.dsireusa.org/incentives/incentive.cfm?Incentive\\_Code=PA08F&re=1&ee=1](http://www.dsireusa.org/incentives/incentive.cfm?Incentive_Code=PA08F&re=1&ee=1)

<sup>40</sup> <http://www.google.com/earth/index.html>



Figure 12: Potential Ground Source Energy Off Takers shows the physical relationship of the Jeddo discharge and each off taker. Table 2: Potential Ground Source Off Takers shows the linear distances and elevation differences from each site to the shortest point to the stream flow. Some systems will be more cost effective than modeled here if they are allowed to place their heat exchanges in the Little Nescopeck Creek, but these environmental impacts and concerns will need to be specifically reviewed.

**Table 5: Potential Ground Source Off Takers<sup>41</sup>**

Potential Ground Source Energy Of Takers		
	Linear Distance (ft)	Elevation Difference (ft)
Keystone High School	2400	115
Drums Elementary	1500	87
Assisted Living Facility	1100	15

Some market research showed that installed costs average approximately \$11k/ton for larger systems in the 100-150 ton range.<sup>42</sup> These costs were for a full turnkey system with approximately 70 individual (room specific) heat exchangers which would be appropriate for a retrofit application such as the three potential off takers as mentioned above. Obviously the final pricing will depend on many other variables but this cost should be indicative of a real current cost for comparable systems in similar climates. Further study of the number of degree heating and cooling days for this area along with the heat loads for each building should be conducted to determine the feasibility of such a ground source heat pump arrangement.

A RETScreen economic model was created assuming a 15,000 ft<sup>2</sup> building with a heating and cooling load of 40 Watts/m<sup>2</sup>. Other assumptions included EIA average PA state pricing for natural gas heat and electricity assuming a 90% efficient natural gas furnace and a seasonal coefficient of performance of 3.5 for the baseline system. The new system assumed a 17 ton heating and cooling system, closed loop water source heat pumps with water temperatures assumed to follow ground temperatures from the included historical data in Appendix I: Geothermal Heat Pump RETScreen Model Results. The cost of the system was modeled at \$13,900 per ton capacity due to the smaller size of the system.

This system provides a 23.9 year simple payback. As with the hydroelectric project, other grant and loan programs are available that may be used to enhance the financing and overall viability of this project. The DSIRE website<sup>43</sup> has the most comprehensive listing of these programs and grants.

<sup>41</sup> These distances are calculated from the closest point of access to the Jeddo Discharge stream; some systems may be able to achieve a shorter interconnection with the Little Nescopeck creek.

<sup>42</sup> Verbal quoted costs from recommended installers from heat exchanger manufacturers, November 2010.

<sup>43</sup> <http://dsireusa.org/incentives/index.cfm?re=1&ee=1&spv=0&st=0&srp=1&state=PA>

## Summary and Conclusions

The U.S. Environmental Protection Agency (EPA), in accordance with the RE-Powering America’s Land initiative, selected the Jeddo Tunnel Discharge site for a feasibility study of renewable energy potential<sup>44</sup>. Citizens of the area, city planners, and site managers are interested in redevelopment uses for this resource as remediation costs are estimated at \$15 million over the next 20 years<sup>45</sup> for a passive treatment system. The purpose of this report is to assess technical and economic viability of the site for hydroelectric and geothermal energy production. In addition, the report outlines financing options that could assist in the implementation of a system.

Economically, the project appears feasible under the stated assumptions. Table 6: Hydro System Performance outlines the basic economic performance of the system. The excess revenue could be used to put towards a fund to clean up mine drainage or local education of schoolchildren about the history and necessary measures of mining, or general energy education. Locating a third party to undertake the financing liability and contract negotiations should not be difficult but finding a party not interested in making a profit may be difficult. Perhaps a nonprofit entity would be more interested than typical developers.

**Table 6: Hydro System Performance**

Hydro System Performance Including Job Creation Estimates								
System Size (kW)	Turbine Type	Turbine Design Flow (m <sup>3</sup> /sec)	Annual Output (kWh/yr)	System Cost	Energy Production Cost (\$/kWh)	Simple Payback Period (years)	Jobs Created (construction)	Cash Grant Utilization
247	Kaplan	4.7	1,162,453	\$2,014,233	0.0796	21.5	22.4	No
247	Kaplan	4.7	1,162,453	\$2,014,233	0.0796	17.4	22.4	Yes
405	Crossflow	5.8	1,029,433	\$2,063,516	0.0913	21.3	22.9	Yes

Next steps should include the clarification of whether or not this facility can meet the definition of ‘hydrokinetic facility’<sup>46</sup> as well as the exploration of virtual net metering policy in the area. Given the nature of the project and its benefits to both the community and the environment, efforts should be made to pursue other grants and low interest loans that could increase the financial viability of the project. Also, further investigation of the optimization of the height of the dam and verification of the annual flow characteristics, which are contingent upon planned remediation within the drainage basin, should be undertaken.

The assumption of wheeling the power at current electricity costs is contingent upon the utility agreeing to this proposition. If this proves impossible, selling the electricity to an off taker would result in a substantially lower cost of energy or wheeling charges imposed by the utility would also drive the effective cost of electricity down. The possibility of virtually net metering this facility is quite realistic, as it may be as simple as placing an off takers name on the electricity bill for the production facility.

<sup>44</sup> [http://www.epa.gov/renewableenergyland/docs/develop\\_potential/drums.pdf](http://www.epa.gov/renewableenergyland/docs/develop_potential/drums.pdf)

<sup>45</sup> Hewitt, Michael (2006, October) “Jeddo Tunnel Abandoned Mine Drainage Passive vs. Active Treatment Cost Estimates” EPCAMR; Eastern Pennsylvania Coalition of for Abandoned Mine Reclamation

<sup>46</sup> <http://www.treasury.gov/initiatives/recovery/Documents/guidance.pdf> pg. 13-14

Further investigation into increasing the height of the dam for additional head pressure could show that an additional 2-10 ft in additional dam height would improve the lifecycle cost of the project and should be investigated further. The hydroelectric turbine was modeled as a single-regulated Kaplan type machine because of the low head of the site and that there are many commercially available units for this design flow. Crossflow turbines are also a good option as they are cost competitive and may offer benefits in reduced civil scopes and reduced maintenance. Selection of a hydroelectric turbine that still produces electrical energy at low flows (approximately 0.85 to 1 cubic meters per second) is critical as flows during the summer months and drought can typically reach these levels and there seems to be no cost effective advantage to using a significantly larger turbine to capture more energy from the high flow periods.

Geothermal heat pumps may be able to provide paybacks of less than 25 years, or even less when combined with state and federal loans and incentives. Further study into the environmental impacts as well as seasonal water temperatures and land use issues are needed.

This project poses a great opportunity to produce carbon free energy from a source that is otherwise simply a pollutant. The educational value this facility could be used to deliver about energy, the coal industry and its history, environmental awareness of the local watersheds, etc is not quantifiable but should be highly considered.

Overall the hydroelectric project looks viable economically and technically. The project would offset approximately 63,497 metric tons of CO<sub>2</sub>, 316 metric tons of SO<sub>2</sub>, and 138 metric tons of NO<sub>x</sub> emissions, and generate 69TWh of electricity in its design life. Additionally, it would create approximately 28 jobs in construction and 19 job-years, or 0.39 jobs/year for O&M over the life of the project.

**Appendix A: Drums Elementary Electricity Bills**

Drums 2010

# Hazleton Area School District

## Account Details by Building [OR04]

Vendors	All Vendors
Building Types	All Building Types
Utility Types	All Utility Types
Buildings	
Accounts	All Accounts
Months	All Months
Year	2010

	Start Date	End Date	Days	Use	Reg KW	Billed KW	Cost	Unit Cost
<b>Drums Elementary / Middle</b>				200	Elementary School 0			
59709-26003				Mtr #: 85342540				
Electric (KWH)	Pennsylvania Power & Light		Mtr Mult: 240.0000	Rate: GS3	Old Turnpike Road			
	06/25/2009	07/27/2009	32	34,080.000	0	112	\$3,143.17	\$0.09
	07/27/2009	08/26/2009	30	36,240.000	0	131	\$3,482.31	\$0.10
	08/26/2009	09/25/2009	30	49,920.000	0	211	\$5,155.92	\$0.10
	09/25/2009	10/26/2009	31	51,600.000	0	195	\$5,057.86	\$0.10
	10/26/2009	11/25/2009	30	51,360.000	0	201	\$5,115.54	\$0.10
	Electric (KWH) Subtotal:			223,200.000			\$21,954.80	\$0.10
101359				Mtr #:				
Trash / Waste (Service)	Slusser Sons Inc.		Mtr Mult: 0.0000	Rate:	85 S. Old Turnpike Road			
	07/11/2009	08/27/2009	57	0.000	0	0	\$150.00	\$0.00
	09/15/2009	09/25/2009	10	0.000	0	0	\$300.00	\$0.00
	Trash / Waste (Service) Subtotal:			0.000			\$450.00	\$0.00
0034400000-0				Mtr #:				
Sewer (Service)	Butler Township Authority		Mtr Mult: 0.0000	Rate:	85 S. Old Turnpike Road			
	04/6/2009	07/8/2009	93	279,172.000	0	0	\$2,462.30	\$0.01
	07/8/2009	10/6/2009	90	192,158.000	0	0	\$1,694.83	\$0.01



Sewer (Service) Subtotal:	471,330.000	\$4,157.13	\$0.01
<b>Drums Elementary / Middle Subtotal:</b>		<b>\$26,561.93</b>	
<b>Report Total</b>		<b>\$26,561.93</b>	

Drums 2009

# Hazleton Area School District

## Account Details by Building [OR04]

Vendors	All Vendors
Building Types	All Building Types
Utility Types	All Utility Types
Buildings	
Accounts	All Accounts
Months	All Months
Year	2009

	Start Date	End Date	Days	Use	Reg KW	Billed KW	Cost	Unit Cost
<b>Drums Elementary / Middle</b>				200	Elementary School 0			
59709-26003				Mtr #: 85342540				
Electric (KWH)	Pennsylvania Power & Light		Mtr Mult: 240.0000	Rate: GS3	Old Tumpike Road			
	06/24/2008	07/24/2008	30	33,840.000	0	109	\$3,065.52	\$0.09
	07/24/2008	08/22/2008	29	32,880.000	0	124	\$3,192.10	\$0.10
	08/22/2008	09/24/2008	33	52,320.000	0	216	\$5,299.94	\$0.10
	09/24/2008	10/23/2008	29	46,800.000	0	209	\$4,927.13	\$0.11
	10/23/2008	11/24/2008	32	60,720.000	0	215	\$5,729.74	\$0.09
	11/24/2008	12/26/2008	32	62,400.000	0	209	\$5,747.26	\$0.09
	12/26/2008	01/27/2009	32	58,800.000	0	208	\$5,588.74	\$0.10
	01/27/2009	02/25/2009	29	58,320.000	0	211	\$5,606.14	\$0.10
	02/25/2009	03/26/2009	29	57,840.000	0	208	\$5,545.15	\$0.10
	03/26/2009	04/27/2009	32	58,320.000	0	211	\$5,606.14	\$0.10
	04/27/2009	05/28/2009	31	49,680.000	0	211	\$5,143.06	\$0.10
	05/28/2009	06/25/2009	28	36,240.000	0	196	\$4,203.08	\$0.12
	Electric (KWH) Subtotal:			608,160.000			\$59,654.00	\$0.10
1-30433				Mtr #:				
Propane (Gal.)	Modern Gas Sales Inc PA		Mtr Mult: 0.0000	Rate:	Drums El./Mid. School			

	07/1/2008	11/24/2008	146	8,724.000	0	0	\$19,192.80	\$2.20
	11/24/2008	01/9/2009	46	9,001.000	0	0	\$19,802.20	\$2.20
	01/9/2009	03/4/2009	54	9,199.000	0	0	\$20,237.80	\$2.20
	03/4/2009	06/26/2009	114	7,264.000	0	0	\$15,980.80	\$2.20
	Propane (Gal.) Subtotal:			34,188.000			\$75,213.60	\$2.20
101359				Mtr #:				
Trash / Waste (Service)	Slusser Sons inc.		Mtr Mult: 0.0000		Rate:		85 S. Old Turnpike Road	
	02/13/2009	02/20/2009	7	0.000	0	0	\$80.00	\$0.00
	Trash / Waste (Service) Subtotal:			0.000			\$80.00	\$0.00
0034400000-0				Mtr #:				
Sewer (Service)	Butler Township Authority		Mtr Mult: 0.0000		Rate:		85 S. Old Turnpike Road	
	06/1/2008	10/1/2008	122	183,085.000	0	0	\$1,614.81	\$0.01
	10/1/2008	01/8/2009	99	350,210.000	0	0	\$3,088.85	\$0.01
	01/8/2009	04/6/2009	88	363,342.000	0	0	\$3,204.68	\$0.01
	Sewer (Service) Subtotal:			896,637.000			\$7,908.34	\$0.01
<b>Drums Elementary / Middle Subtotal:</b>							<b>\$142,855.94</b>	
<b>Report Total</b>							<b>\$142,855.94</b>	

# Hazleton Area School District

## Account Details by Building [OR04]

Vendors	All Vendors
Building Types	All Building Types
Utility Types	All Utility Types
Buildings	
Accounts	All Accounts
Months	All Months
Year	2008

	Start Date	End Date	Days	Use	Reg KW	Billed KW	Cost	Unit Cost
<b>Drums Elementary / Middle</b>				200	Elementary School 0			
59709-26003				Mtr #: 85342540				
Electric (KWH)	Pennsylvania Power & Light		Mtr Mult: 240.0000	Rate: GS3	Old Tumpike Road			
	06/25/2007	07/25/2007	30	33,120.000	0	110	\$3,099.41	\$0.09
	07/25/2007	08/23/2007	29	33,120.000	0	105	\$2,996.41	\$0.09
	08/23/2007	09/25/2007	33	52,560.000	0	223	\$5,376.10	\$0.10
	09/25/2007	10/24/2007	29	47,040.000	0	231	\$5,167.70	\$0.11
	10/24/2007	11/26/2007	33	57,120.000	0	209	\$5,464.49	\$0.10
	11/26/2007	12/26/2007	30	55,680.000	0	211	\$5,409.14	\$0.10
	12/26/2007	01/25/2008	30	54,480.000	0	211	\$5,352.74	\$0.10
	01/25/2008	02/25/2008	31	60,000.000	0	219	\$5,739.09	\$0.10
	02/25/2008	03/26/2008	30	59,760.000	0	211	\$5,632.08	\$0.09
	03/26/2008	04/24/2008	29	52,560.000	0	205	\$5,182.76	\$0.10
	04/24/2008	05/23/2008	29	48,720.000	0	204	\$4,969.06	\$0.10
	05/23/2008	06/24/2008	32	43,200.000	0	212	\$4,773.29	\$0.11
	Electric (KWH) Subtotal:			597,360.000			\$59,162.27	\$0.10
01-788-1991-8-655-3				Mtr #: 570-788-1991				
Telephone (Minutes)	Frontier		Mtr Mult: 0.0000	Rate:	Drums Elementary / Middle			
	07/1/2007	07/31/2007	30	0.000	0	0	\$294.58	\$0.00



	08/1/2007	08/31/2007	30	0.000	0	0	\$258.07	\$0.00
	09/1/2007	09/30/2007	29	0.000	0	0	\$261.72	\$0.00
	10/1/2007	10/31/2007	30	0.000	0	0	\$307.02	\$0.00
	11/1/2007	11/30/2007	29	0.000	0	0	\$304.28	\$0.00
	12/1/2007	12/31/2007	30	0.000	0	0	\$-454.68	\$0.00
	01/1/2008	01/31/2008	30	0.000	0	0	\$86.80	\$0.00
	02/1/2008	02/29/2008	28	0.000	0	0	\$131.24	\$0.00
	03/1/2008	03/31/2008	30	0.000	0	0	\$-149.66	\$0.00
	04/1/2008	04/30/2008	29	0.000	0	0	\$206.86	\$0.00
	05/1/2008	05/31/2008	30	0.000	0	0	\$2.95	\$0.00
	06/1/2008	06/30/2008	29	0.000	0	0	\$67.62	\$0.00
	Telephone (Minutes) Subtotal:			0.000			\$1,316.80	\$0.00
1-30433				Mtr #:				
Propane (Gal.)	Modern Gas Sales Inc PA			Mtr Mult: 0.0000	Rate:	Drums El./Mid. School		
	07/1/2007	11/15/2007	137	9,001.000	0	0	\$12,871.43	\$1.43
	11/15/2007	01/9/2008	55	9,003.000	0	0	\$12,874.29	\$1.43
	01/9/2008	02/25/2008	47	9,000.000	0	0	\$12,870.00	\$1.43
	02/25/2008	05/27/2008	92	8,400.000	0	0	\$12,012.00	\$1.43
	Propane (Gal.) Subtotal:			35,404.000			\$50,627.72	\$1.43
0034400000-0				Mtr #:				
Sewer (Service)	Butler Township Authority			Mtr Mult: 0.0000	Rate:	85 S. Old Turnpike Road		
	07/1/2007	09/30/2007	91	67.000	0	0	\$7,035.00	\$105.00
	10/1/2007	12/31/2007	91	67.000	0	0	\$7,035.00	\$105.00
	01/1/2008	03/31/2008	90	67.000	0	0	\$7,035.00	\$105.00
	04/1/2008	06/30/2008	90	67.000	0	0	\$7,035.00	\$105.00
	Sewer (Service) Subtotal:			268.000			\$28,140.00	\$105.00
<b>Drums Elementary / Middle Subtotal:</b>							<b>\$139,246.79</b>	
<b>Report Total</b>							<b>\$139,246.79</b>	

# Appendix B: Conceptual Dam Design





ENGINEERS / CONSULTANTS / CM

Paul C. Rizzo Associates, Inc.  
500 Penn Center Boulevard • Penn Center East, Building 5, Suite 100 • Pittsburgh, PA 15235  
Phone (412) 856-9700 • Fax (412) 856-9749  
www.rizzoassoc.com

August 27, 2010  
Project No. 10-4414

Mr. Joseph Owen Roberts  
National Renewable Energy Laboratory  
1617 Cole Blvd.  
Golden, CO 80401-3393

**TRANSMITTAL  
DRAFT CONCEPTUAL DESIGN  
JEDDO TUNNEL DAM & HYDROELECTRIC FACILITY**

Dear Mr. Roberts:

This letter presents Paul C. Rizzo Associates' (RIZZO) conceptual design for the construction of an embankment Dam and hydroelectric facility at the outflow of the Jeddo Mine Drainage Tunnel. It has been prepared for the National Renewable Energy Laboratory (NREL) in accordance with our June 25, 2010 Proposal.

**INTRODUCTION**

The Jeddo Tunnel is a man-made water level drainage tunnel constructed approximately 100 years ago to dewater deep mined coal measures in the Eastern Middle Anthracite Field. The tunnel drainage system drains water from four major coal basins: Big Black Creek, Little Black Creek, Cross Creek, and Hazelton. The tunnel has continued to drain the abandoned mine workings after the collapse of the deep industry in the 1950s. The tunnel currently drains over 30 square miles (mi<sup>2</sup>) with an average discharge of 80 cubic feet per second (cfs) into the Little Nescopeck Creek.

The Little Nescopeck Creek, a tributary to Nescopeck Creek, is severely impacted by the poor quality of the water discharged from the tunnel. The water discharged through the tunnel is characterized as Acid Mine Drainage (AMD).



## PROJECT DESCRIPTION

The conceptual design for the construction of a low head hydroelectric facility at the Site will consist of an earth embankment dam approximately 22 feet (ft) high and a small powerhouse that will house the hydroelectric equipment. The geography and geology around the Tunnel Outlet play a significant role in the siting of the proposed Dam. They determine the optimum location for the Dam, what materials are available for construction, and the foundation conditions for the Dam.

## SITE LOCATION AND DESCRIPTION

The Site for the proposed Jeddo Tunnel Dam system is located approximately 1.0 mi south of Drums and 3.4 mi northeast of Conyngham, Luzerne County. From Conyngham, take County Highway 38 3.0 mi east, turn left onto South Old Turnpike Road, and make a right onto Dean Street. At the end of Dean Street, stop and walk southeast to the old service road that runs behind several private residences. Approximately 600 ft after passing under the tree line, turn left and the Jeddo Tunnel Outlet is located approximately 150 ft northwest of the service road. There is an elevation drop of roughly 42 ft from the service road at Elevation (El.) 1062 ft to the outlet of the Jeddo Tunnel at approximately El. 1020 ft. A Site Location Plan is provided on *Figure 1*.

The location is heavily wooded with a mixture of deciduous and evergreen trees (average 12 to 18 inch in diameter). The undergrowth varies from light (dead leaves and ferns) to heavy (bushes, thorns, and small trees). From the site visit, the ground surface appears to be made of a thin layer of heavily organic soil overlaying much harder glacial till and alluvial soil. The run of the creek from the Tunnel Outlet (El. 1020 ft) to the confluence with Little Nescopeck Creek (El. 995 ft) is approximately 1,600 to 1,700 ft. The stream bank slopes are generally less than 1H:1V at the tunnel outlet. The left (looking downstream) stream bank slope begins to top off at approximately El. 1052 ft and the right stream bank slope begins to top off at approximately El. 1045 ft. The stream bank slopes gradually fall off in height further downstream of the Tunnel Outlet. The stream bank slopes are generally 2H:1V to 1.5H:1V. At approximately 600 ft downstream, the bank is only 7 to 10 ft above the streambed elevation. The ground surface above the left stream bank slopes downward towards the northwest with a difference in elevation of 22 ft over a horizontal distance of 320 ft. The ground surface above the right stream bank slopes upwards from the Jeddo Tunnel for a total difference in elevation of 6 ft over a horizontal

distance of 220 ft, then downwards for difference in elevation of 16 ft over a horizontal distance of 160 ft.

The existing Tunnel Outlet is of masonry construction, some concrete repair work has been performed on the structure in the past. The only other structure in the vicinity is an old abandoned United States Geological Survey (USGS) Stream Gage. There were no above ground utilities observed during the site visit, nor were there any signs of the presence of underground utilities. The area immediately around the tunnel outlet may have been built up with mine cuttings and spoil, but has since been overgrown with vegetation.

Based on field observations and topographical data, a site well suited for the Dam is located approximately 250 ft downstream of the Jeddo Tunnel Outlet. At this location, the stream bed is estimated to be at El. 1018 ft. The tops of the side slopes at this location downstream of the Tunnel Outlet are between El. 1040 and El. 1045 ft. The streambed at this location is approximately 25 ft wide and the span across the valley from the top of the one side slope to the other is approximately 130 ft. Further information on the Site location and sketches are included in the field log provided in *Attachment A*. Photographs of the Site are provided in *Attachment B*.

#### **SITE GEOLOGIC CONDITIONS**

The Jeddo Tunnel Site lies in a stable geologic region that has experienced only minor earthquake activity, with no measured historical epicenter located within 50 mi of the Site.

The Site lies within the Appalachian Mountain Section of the Ridge and Valley Province that consists of long, narrow ridges and broad to narrow valleys exhibiting moderate to very high relief. These ridges and valleys are a direct result of lithologic disparities in erosional resistance and the folded and faulted structures developed in the geologic past, when the mountains were built, during the Alleghanian Orogeny.

This Province is primarily a zone containing Cambrian to Pennsylvanian rocks that were folded and faulted during the Alleghanian Orogeny that occurred during late Pennsylvanian through Permian times, nearly 300 million years ago. In addition to the geologic events that affected the entire Ridge and Valley Physiographic Province, three glacial advances affected the site-vicinity during the Pleistocene Epoch.

The Jeddo Tunnel Site region is located in a stable continental region (SCR) characterized by low rates of crustal deformation with no active plate boundary conditions. There is no evidence for late Cenozoic seismogenic activity of any tectonic feature or structure within the Site region (within 200 mi, 322 kilometer (km)).

The Site is within 10 mi of the Susquehanna River near the southern edge of glaciation in Pennsylvania. The Jeddo Tunnel Site area is located within the Anthracite Upland Section of the Ridge and Valley Physiographic Province, and is bordered by the Susquehanna Lowland Section to the north and the Blue Mountain Section to the south. The Site area is underlain by the Lower Mississippian formations, with the Mauch Chunk Formation bedrock directly beneath the Site. The Mauch Chunk Formation generally consists of a lower unit of interbedded grayish-red shale, siltstone, sandstone, and some conglomerate, and an upper unit consisting of light-gray calcareous quartz sandstone. Some non-red zones exist including Loyalhanna Member, which along the Allegheny Front (Blair County to Sullivan County) is greenish-gray, calcareous crossbedded sandstone. Also includes Greenbrier Limestone Member, and Wymps Gap and Deer Valley Limestone, which are tongues of the Greenbrier.

The most recent geologic influence on the Site was the Late Illinoian and Pre-Illinoian glaciations that deposited glacial materials (thin, clayey to sandy till covering 10 to 25 percent of the ground) on the bedrock surface. The topography within 5 mi (8 km) of the Site consists of low to moderately high, linear ridges and valleys that primarily follow structural trends of the local geologic formations.

The local geologic formations have been subjected to a series of mountain-building episodes, including the Grenville, Taconic, and Alleghanian orogenies. The local structure of the Ridge and Valley Province was imparted to the area during the Alleghanian Orogeny at the end of the Permian Period, nearly 250 million years ago. The Site geologic history has been quiet since the end of the Permian; at that time, the local portion of the crust became more stable and tensional stresses predominated through the Cretaceous Period. The only disturbance of this quiet state was the advance of several ice sheets in the Pleistocene; however, since the Site is located at the extreme southern limit of the glaciated area, the ice sheets were at their thinnest and any crustal depression or subsequent rebound from the ice load has been minimal.

## PROBABLE SUBSURFACE CONDITIONS

Based on the regional geology of the Site, RIZZO is assuming the following subsurface conditions to provide a basis for our conceptual design of the facility. The thin organic topsoil layer is underlain with glacial till of an unknown depth, and the glacial till is likely comprised of silty sand and coarse grained material with little or no cohesive properties. Beneath the glacial till overburden layer lays the bedrock. The bedrock is likely comprised primarily of interbedded shale and sandstone. The foundation of the proposed embankment Dam will be located within the overburden layer, so excavation down to bedrock is unlikely.

## ENGINEERING CHARACTERISTICS OF LOCAL SOILS

Based on our experience with a nearby power plant site located approximately 10 miles to the northwest of the Site, probable values for index properties for the subsurface materials are summarized in *Table 1* below.

**TABLE 1  
MATERIAL PROPERTIES**

MATERIAL	UNIT WEIGHT (PCF)			FRICTION ANGLE (DEG)	COHESION (PSF)	WATER CONTENT (%)
	DRY	MOIST	SAT.			
Glacial Overburden	109	121	144	32	0	11.0
Mauch Chunk Formation	169	170	170	40	7300	0.5

The glacial till material, according to the regional geology, is primarily classified as silty sand and coarse grained material. The overburden layer is assumed to have zero cohesion, but a friction angle on the order of 32 degrees. The unit weight of the material at time of excavation will be lower than that of a well-graded engineered fill of the same material.

## DAM CONCEPTUAL DESIGN AND BUDGETARY COST ESTIMATE

The conceptual design is to construct a new Earth Fill Dam approximately 250 ft downstream of the Tunnel Outlet. The cost estimate for the dam construction assumes that a source of engineered fill material is locally available at the time of construction. In developing the conceptual design, modern safety standards were considered, as set forth by the U.S. Army

Corps of Engineers, the Pennsylvania Department of Environmental Protection Dam Safety & Encroachments Act (Act 325 of 1978), and Pennsylvania Code Title 25, Chapter 105, Dam Safety and Waterway Management.

### **Earth Fill Dam**

The proposed Dam will be 22 ft high and 150 ft long, with a crest width of 12 ft. The upstream and downstream shells will be comprised of on-site borrow sources. A 3 horizontal to 1 vertical 3H:1V slope will be used for both the upstream and downstream slopes of the embankment dam. The design crest will be at El. 1040 with a slight over-build to account for potential settlement. A minimum 3-foot excavation of the existing surface material is anticipated for the Dam to be founded on glacial till and to reduce the abutment side slopes for safety. The total storage volume of the impoundment area is on the order of 2.7 million gallons of water. Conceptual drawings, including a plan view, cross sections, and details of the proposed Earth Fill Dam, are shown on *Figures 2 and 3* provided in *Attachment C*.

A typical earth fill Dam would be constructed with a clay core for seepage protection. However, the existence of a local source of clay fill material is unknown at this time, and given the regional geology, unlikely to exist. In addition, the local soil is most likely comprised of a sandy glacial till, which is fairly free draining. Therefore, RIZZO's conceptual design for the embankment Dam includes a vertical chimney filter attached to a horizontal drain blanket extending to the toe of the Dam to provide seepage control and prevent piping within the Dam. The drainage blanket will extend to fully cover the abutment contacts to reduce the possibility of piping of materials through the abutments. All material for both fill and filter will be placed and compacted in 1 foot lifts.

Upon completion, riprap will be placed on the upstream face, and the downstream face will be mulched and seeded to prevent erosion, which is beneficial from both Dam safety and environmental perspectives. A drainage swale along the downstream toe of the Dam will divert surface water from the Dam.

### **Spillway**

The design of the Dam is subject to guidelines set forth by the Federal Energy Regulatory Commission (FERC). Based on the lack of developed areas downstream from the proposed Dam, we have assumed that the structure will be classified as a low hazard dam. The Dam is



located within a rural area, and has a relatively small storage capacity, the release of which would most likely be confined to the river channel in the event of a failure, and therefore would represent no danger to human life.

The drainage area upstream of the Dam is approximately 0.5 mi<sup>2</sup>. To pass the inflow design flood (IDF) storm event over this drainage area, as well as the mine drainage from the tunnel outlet, a spillway is required. The proposed spillway is a drop inlet structure located upstream of the Dam. The spillway inlet structure will be a concrete box culvert located at the upstream base of Dam, and rise to the normal operating level of the impoundment.

### **Powerhouse**

The ultimate purpose of the proposed Dam is to impound the mine drainage water for the generation of electricity. The powerhouse structure will be constructed at the downstream toe of the Dam, offset from the centerline to the left (looking downstream). The penstock will run underneath the embankment to an intake structure on the upstream side. The cost of the powerhouse is based on the estimated cost of the turbine unit, the penstock, and the estimated amount of cast-in-place and pre-cast concrete required for the construction of the powerhouse, penstock, and intake structure.

The conceptual design details a general layout for the powerhouse and intake structures. The powerhouse, penstock and intake structure will need to be sized based off of the turbine selected for the Project. RIZZO performed some preliminary calculations, Concluded that a net head of 18 ft and a design flow of 80 cfs, the estimated theoretical power output from the hydro system is 122 kilowatts. The actual power output will be less due to efficiency losses from the hydroelectric system.

### **Budgetary Cost Estimate**

The associated costs for the construction of the Jeddo Tunnel Dam and main supporting structures are summarized in the table provided in *Attachment D*. Cost estimates were developed based on quantity take-offs and RIZZO' experience with similar projects.

The cost to construct the Earth Fill Dam is estimated to be \$2.0 Million. This includes a construction contingency of 20 percent, which is consistent with typical industry practice for

construction cost estimation at this stage of design. As the design progresses, this contingency will reduce.

The costs provided assume that the appropriate permits and authorizations are readily obtainable from state and federal regulatory agencies. Costs associated with wetland mitigation are not regarded as applicable, and thus have not been considered.

Consideration was given to the feasibility of a mass concrete dam in place of an Earth Fill Dam. After review of the quantities and constructability issues, it was determined that a concrete dam would be significantly more expensive (i.e., twice the cost) than the Earth Fill Dam. The additional cost is primarily due to the high cost per unit for the concrete, the increased excavation depth to obtain a suitable foundation, and the necessary foundation improvements required of such a structure.

#### **REPORT LIMITATIONS**

The conceptual design presented in this letter has been formulated on the basis of the information provided by NREL and the assumptions stated herein. Any significant changes in this information should be brought to RIZZO's attention for review.

This letter has been prepared for the exclusive use of the NREL for the feasibility evaluation of the construction of a hydroelectric facility at the Jeddo Tunnel Project. Our recommendations are based on the assumed subsurface conditions at the Site based on the regional geology and our experience with other sites in northeastern Pennsylvania. RIZZO is not responsible for the conclusions, opinions, or recommendations of others based on these preliminary data.

#### **SUMMARY**

Paul C. Rizzo Associates, Inc. has prepared this conceptual design report based on field observation of the Site and modern engineering practices to assess the feasibility of the design of a Jeddo Tunnel Dam and hydroelectric facility. We have prepared preliminary sketches (*Figures 2 and 3 in Attachment C*) and estimated costs for Dam design and construction. Our evaluation indicates that an Earth Fill Dam can be installed for approximately \$2.0 million.

If you have any questions or concerns please contact me at (412) 825-2008, or by email at [john.osterle@rizzoassoc.com](mailto:john.osterle@rizzoassoc.com).

Respectfully submitted,  
***Paul C. Rizzo Associates, Inc.***

John P. Osterle, P.E.  
Vice President – Dams & Water Resources Projects

Kevin R. Cass, P.E.  
Project Engineer

JPO/KRC/sjr/crb

Attachments

DRAFT

DRAFT

ATTACHMENT A  
FIELD LOG



ENGINEERS & CONSULTANTS

FIELD ACTIVITY DAILY LOG

T U E	DATE	8	3	10
	NO.	—		
	SHEET	1	OF	4

PROJECT NAME JEDDO TUNNEL

PROJECT NO. 10-4414

FIELD ACTIVITY SUBJECT: SITE VISIT - FEASIBILITY OF LOW HEAD DAM

DESCRIPTION ON DAILY ACTIVITIES AND EVENTS:

0900 KEVIN CASS (KRC) MET WITH JOSEPH OWEN ROBERT (JOR) OF THE NATIONAL RENEWABLE ENERGY LABORATORY (NREL) AND PETER HAENTJENS (PH) OF EASTERN MIDDLE ANTHRACITE REGION RECOVERY, INC. (EMARR), AND DROVE TO THE SITE OF THE PROPOSED DAM.

0910 KRC ARRIVED AT WALK-IN POINT ALONG DEAN ST., AT A CORNER BEND IN THE ROAD, WITH TWO GRAVEL DIRT ROADS RUNNING EAST AND SOUTH. KRC WALKED UP THE HILL ALONG THE SOUTH ROAD AND TURNED LEFT. THE DIRT ROAD RUNS BEHIND 3 OR 4 PRIVATE RESIDENCES, THEN INTO THE WOODS.

0917 AFTER WALKING ABOUT 500-600 FT INTO THE WOOD, KRC TURNED LEFT TO WALK DOWN TO THE JEDDO TUNNEL OUTLET, KRC PROCEEDED TO TAKE NOTES PICTURES, GPS READINGS, AND LASER RANGE FINDER READINGS OF THE AREA AROUND THE TUNNEL OUTLET. (SEE ATTACHED CHECKLIST FOR FURTHER DETAIL INTO FINDINGS).

0955 KRC CONTINUED TO WALK DOWN STREAM ALONG THE RIGHT BANK. CREEK RETAINS A RELATIVELY CONSTANT WIDTH OF 20-25 FT. STEEP SIDE SLOPES GRADUALLY DROP OFF FROM ABOUT 40 FT ABOVE CREEK BED AT THE OUTLET TO 5-6 FEET ABOUT 600 FT DOWNSTREAM.

1005 AT ABOUT 750 FT DOWN STREAM KRC OBSERVED THE REMNANTS OF AN OLD DAM. THE STREAM BED WIDENS TO ABOUT 50 FT. THE OLD DAM EXTENDS FROM THE RIGHT BANK OUT ABOUT 30 FT. THE REMAINING IS BLOCKED UP WITH DOWNED TREES PILED UP. THE WOODS OPEN UP TO A FIELD ACROSS ON THE LEFT BANK.

1015 KRC CONTINUED DOWNSTREAM AND CROSSED OVER AT AN OLD BRIDGE (ABOUT 1/4 MILE DOWNSTREAM OF THE TUNNEL OUTLET). KRC WALKED BACK UP THE LEFT BANK TOWARDS THE TUNNEL.

1030 KRC AND OTHERS STOPPED ABOUT 250 FT DOWNSTREAM OF TUNNEL OUTLET, [OVER] →

VISITORS ON SITE:

*[Handwritten signature]*

CHANGES FROM PLANS AND SPECIFICATIONS, AND OTHER SPECIAL ORDERS AND IMPORTANT DECISIONS.

*[Handwritten signature]*

WEATHER CONDITIONS

75°F HAZY AND HUMID. OVERCAST.

IMPORTANT TELEPHONE CALLS

*[Handwritten signature]*

PERSONNEL ON SITE: KEVIN CASS, JOSEPH OWEN ROBERTS, PETER HAENTJENS

FIELD ENGINEER KEVIN CASS *[Signature]*

DATE 8/3/10





ENGINEERS & CONSULTANTS

FIELD ACTIVITY DAILY LOG

T U E	DATE	8	3	10
	NO.	—		
	SHEET	2 OF 4		

PROJECT NAME	JEDDO TUNNEL	PROJECT NO.	10-4414
--------------	--------------	-------------	---------

FIELD ACTIVITY SUBJECT: SITE VISIT...

DESCRIPTION ON DAILY ACTIVITIES AND EVENTS:

THIS AREA IS A LIKELY SPOT FOR THE PROPOSED DAM. KRL SPENT SOMETIME DOCUMENTING THIS AREA. TOP OF RIDGETO CREEK BED HAVE AN ELEVATION DIFFERENCE OF ABOUT 25-30 FT. THE LEFT AND RIGHT RIDGES ARE ABOUT 110-120 FT APART, AS WITH NEAR OUTLET, THE RIGHT BANK IS RATHER STEEP WHILE THE LEFT SLOPE VARIES.


1050 KRL RETURNED TO TUNNEL OUTLET AND DISCUSSED FINDINGS WITH JOR & PH,

1055 LEFT SITE AND RETURNED TO CAR. DROVE AROUND AREA, DOWN TO CONYNGHAM. CROSSED OVER LITTLE NESCOPECK CREEK SEVERAL TIMES TO LOOK AT IT,

1120 ARRIVED NEAR CONFLUENCE OF LITTLE NESCOPECK CREEK WITH NESCOPECK CREEK. WALKED OUT TO NESCOPECK CREEK TO OBSERVE,

1135 WALKED THROUGH WOODS ABOUT 1/4 MILE TO CONFLUENCE, OBSERVED CLEAR WATER MEETING WITH ACID MINE DRAINAGE.

1155 RETURNED TO CARS. DISCUSSED PROJECT MORE. SITE VISIT OVER.



NOTES:

- PH SAID CREEK LEVEL CHANGES ONLY  $\approx$  30 FT FROM TUNNEL OUTLET DOWN TO LITTLE NESCOPECK CREEK.
- JEDDO TUNNEL SHAFT IS 9'x7' FOR MAJORITY, BUT LARGER AT OUTLET.
- TUNNEL WOULD BE FLOODED IF DAM WERE BUILT. POSSIBLE IMPROVEMENT TO WATER CONDITIONS DUE TO LACK OF OXIDATION.

VISITORS ON SITE:

CHANGES FROM PLANS AND SPECIFICATIONS, AND OTHER SPECIAL ORDERS AND IMPORTANT DECISIONS.

WEATHER CONDITIONS

IMPORTANT TELEPHONE CALLS

PERSONNEL ON SITE:

FIELD ENGINEER KEVIN CASS *Kevin P. Cass*

DATE 8/3/10



ENGINEERS & CONSULTANTS

FIELD ACTIVITY DAILY LOG

T U E	DATE	8	3	10
	NO.	—		
	SHEET	3	OF	4

PROJECT NAME	JEDDO TUNNEL	PROJECT NO.	10-4414
--------------	--------------	-------------	---------

FIELD ACTIVITY SUBJECT: SITE VISIT...

DESCRIPTION ON DAILY ACTIVITIES AND EVENTS:

- \* Roughly 2 ft contours
- \* steep side slope on right bank ( $\geq 1:1$ )
- \* left bank plateaus part way up slope, continues down stream but area shrinks and gain a slight slope. (3:1)
- \* left slope only steep ( $\geq 1:1$ ) at the top 10 ft.
- \* area outside of river channel is relatively flat with a slight slope down wards and away from creek.
- \* area behind continues uphill but at a much shallower slope (3:1-5:1)
- \* an initial 4-6 ft feet of creek channel is near vertical and slightly under cut in areas.

The diagram is a hand-drawn topographic map of the site. It features contour lines representing elevation. A central feature is the 'Jeddo Tunnel outlet', shown as a rectangular structure with a trapezoidal opening. Below it, a stream flows downwards, indicated by a 'FLOW' arrow. To the right of the stream, an 'old USGS stream gage' is marked with a small square. Dimensions are provided: a 120 ft width at the top of the tunnel outlet, a 50 ft width at the gage location, and a 20-25 ft width at the bottom of the stream channel. Elevation markers include 'EL ≈ 1020'' at the tunnel outlet, and contour lines labeled '1030'', '1040'', and '1050'' on the right side. The left and right sides of the map are labeled 'RIGHT RIDGE' and 'LEFT RIDGE' respectively. A '65 ft' dimension is noted on the right bank slope.

VISITORS ON SITE:

CHANGES FROM PLANS AND SPECIFICATIONS, AND OTHER SPECIAL ORDERS AND IMPORTANT DECISIONS.

WEATHER CONDITIONS

IMPORTANT TELEPHONE CALLS

PERSONNEL ON SITE: —

FIELD ENGINEER KEVIN CASS *Kevin P. Cass* DATE 8/3/10



Paul C. Rizzo Associates, Inc.  
CONSULTANTS



By KRC . Date 8/3/10 . Subject Jeddo Tunnel  
Chkd. by      . Date      . Site Reconnaissance Check List

Sheet No. 4 of 4 .  
Proj. No. 104414 .

**Surface Vegetation (grass, brush, heavily wooded, lightly wooded):**

Area is heavily wooded. A mix of deciduous and evergreen with an Average tree diameter of 12-18 inches. Under growth varies from light (clever, ferns) to heavy (bushes, thorns, small trees)

**Topography (level, sloping, river or stream, drainage ditches or swales, ponds):**

Sloping downward towards the NW, with an estimated 25-30 foot difference over 1600 foot distance, from Tunnel outlet (El 1020 ft) to Little Nescopeck Creek (El 995 ft). The creek bed is approximately 30 feet below top of ridge with steep side slopes at the tunnel outlet ( $\approx$  El 1050 ft). The steep side slopes gradually fall off. At approximately 600 ft downstream of the Tunnel outlet, the bank is only 7-10 ft above the creek bed.

**Surface Conditions (soft, firm, hard, wet, ponded water, topsoil, fill, disked):**

relatively soft undergrowth in vicinity of tunnel outlet. Area immediately surrounding outlet made up of old mine cuttings and spoil (overgrowth over 100yr period). Dark reddish brown clay w/ high degree of gravel. 1st 8" of ground is soft and moist in some areas. Further D/S near proposed dam site, soil is dryer. It is made up of a thin layer of organic soil overtopping what appears to be glacial or alluvial soil, and rock. several rock outcroppings were observed. Very hard soil after initial 6-8" of organic soil.

**Condition of existing Structures (utilities, buildings, walls, foundations):**

Existing tunnel outlet is constructed of masonry with some concrete repair work visible on the right side. Heavy spalling of concrete for first 2 feet above water surface (4'5" back). An abandoned USGS stream gage exist just downstream of the tunnel along the left bank. No other structures in vicinity of outlet. Remnant of an old wooded dam block up part of the creek about 750 ft D/S of the outlet.

**Utilities (aboveground and/or below ground):**

No above ground utilities observed in the vicinity of the site. No known underground utilities appear to exist.

**ATTACHMENT B  
PHOTOGRAPHS OF THE SITE**

**PHOTO 1: ACCESS ROAD TO SITE**





**PHOTO 2: PATH TO TUNNEL OUTLET OFF ACCESS ROAD**



**PHOTO 3: TUNNEL OUTLET FROM TOP OF RIGHT STREAM BANK**





**PHOTO 4: LOOK DOWN ON JEDDO TUNNEL OUTLE FORM BEHIND**





**PHOTO 5: JEDDO TUNNEL OUTLET FROM LEFT BANK**



**PHOTO 6: JEDDO TUNNEL OUTLET**





**PHOTO 7: TUNNEL OUTLET FROM RIGHT BANK**



**PHOTO 8: LOOKING DOWNSTREAM FROM TUNNEL OUTLET**





**PHOTO 9: LOOKING AT RIGHT STREAM BANK FROM TUNNEL OUTLET**



**PHOTO 10: USGS STREAM GAGE WITH OUTLET IN BACKGROUND**





**PHOTO 11: LOOKING AT LEFT BANK AT TUNNEL OUTLET**



**PHOTO 12: PROPOSED DAM LOCATION FROM RIGHT BANK**





**PHOTO 13: PROPOSED DAM LOCATION FROM LEFT BANK**



DRAFT

ATTACHMENT C  
CONCEPTUAL DRAWINGS



CAD FILE NUMBER 10-4414-A1

CHECKED BY


APPROVED BY

JMJ

08/25/10

DRAWN BY

PLOT 1=1







**DRAFT**

FIGURE 1  
 SITE LOCATION MAP  
 JEDDO TUNNEL DAM  
 AND HYDROELECTRIC FACILITY  
 PREPARED FOR  
 NATIONAL RENEWABLE  
 ENERGY LABORATORY  
 GOLDEN, COLORADO

REFERENCES:  
 U.S.G.S. 7.5 MIN. TOPOGRAPHY MAPS,  
 PENNSYLVANIA-FRELAND, CONYNGHAM, HAZELTON,  
 AND SYBERTSVILLE QUADRANGLES, DATED 2010.




PLOT 1:1  
 DRAWN BY  
 GPC 8-19-10  
 CHECKED BY  
 CAD FILE NUMBER 10-4412-E2



**DRAFT**

FIGURE 2


EMBANKMENT DAM  
 PLAN AND PROFILE  
 JEDDO TUNNEL DAM  
 AND HYDROELECTRIC FACILITY  
 PREPARED FOR  
 NATIONAL RENEWABLE  
 ENERGY LABORATORY  
 GOLDEN, COLORADO



CAD FILE NUMBER 10-4414-E1  
 CHECKED BY JMJ  
 APPROVED BY 08/18/10  
 DRAWN BY  
 PLOT 1:1



**DRAFT**

FIGURE 3  
 EMBANKMENT DAM  
 TYPICAL SECTIONS  
 JEDDO TUNNEL DAM  
 AND HYDROELECTRIC FACILITY  
 PREPARED FOR  
 NATIONAL RENEWABLE  
 ENERGY LABORATORY  
 GOLDEN, COLORADO  
 Paul C. Rizzo Associates, Inc.  
 ENGINEERS & CONSULTANTS



DRAFT

**ATTACHMENT D  
COST ESTIMATE**

**JEDDO TUNNEL DAM AND HYDROELECTRIC FACILITY**

Item	Description	Estimated Quantity & Cost			
		Estimated Quantity	Unit of Measure	Unit Cost	Total Cost Value
1	Mobilization & Demobilization	1	Lump Sum	\$ 75,000	\$ 75,000
2	Site Access and Site Work	1	Lump Sum	\$ 25,000	\$ 25,000
3	Erosion & Sedimentation Controls	1	Lump Sum	\$ 8,000	\$ 8,000
4	Clear and Grub	1.5	acre	\$ 12,500	\$ 18,750
5	Foundation Excavation	2,200	CY	\$ 10	\$ 22,000
6	Engineered Fill Construction	5,200	CY	\$ 19	\$ 98,800
7	Chimney Drain Filter Material	280	CY	\$ 37	\$ 10,360
8	Drainage Blanket Filter Materials	465	CY	\$ 37	\$ 17,205
9	Riprap	175	CY	\$ 35	\$ 6,125
10	Turbine	1	Lump Sum	\$ 750,000	\$ 750,000
11	Concrete (Spillway, Intake, & Powerhouse)	160	CY	\$ 750	\$ 120,000
12	Conduit (for Spillway Outlet and Penstock)	285	LF	\$ 1,000	\$ 285,000
				SUBTOTAL	\$ 1,436,240
13	20% Contingency				\$ 287,248
				SUBTOTAL	\$ 1,723,488
14	Engineering Design and PADEP Permitting*	1	Lump Sum	\$ 172,349	\$ 172,349
15	Engineering and Construction Supervision	1	Lump Sum	\$ 120,644	\$ 120,644
	<b>Total Cost</b>				<b>\$ 2,016,481</b>

\* FERC Licensing effort not included in cost estimate.

**Appendix C: Crossflow Turbine Information**

# HYDROPOWER TURBINE SYSTEMS, INC.

PO Box 736  
 Hayes, VA, USA 23072  
 TEL: 804-360-7992  
 FAX: 866-552-9946  
 Email: hts-inc@hts-inc.com

August 10, 2010

## **ESTIMATE**

**RE: P-2497-1 HYDRO ELECTRIC PROJECT in PENNSYLVANIA  
 OSSBERGER TURBINE/GENERATOR SET**

Hydro electric equipment proposal for budgetary purposes, based on one OSSBERGER Turbine/Generator Set with automatic control feature (head level controller), for grid parallel operation, rated for:

Static Head assumed	HG	=	9.5 m (from head- to tailwater level)
Nethead given	HN	=	9.0 m
Max. Flow	Q	=	205 cfs
Min. Flow	Q	=	20 cfs
Turbine Output	PT	=	440 kW
Generator Output	PG	=	405 kW
Nominal speed	n	=	113/1220 rpm


Scope of Supply:

- 1 OSSBERGER Turbine (SH1000 double cell)
- 2 Baseframe
- 3 OSSBERGER Water Level Regulator (automatic operation)
- 4 Turbine Control Panel
- 5 Transition Piece and Draft Tube
- 6 Service Valve (not required)
- 7 FLENDER Speedincreaser with Couplings
- 9 HITZINGER Induction Generator (450 kW, 1200 RPM, 480V/3/60, RTD's, with overspeed capability)
- 10 Electric Switchgear (not included)


**Price Estimate : EUR 470,000**

Price stated in Euros, due to the fluctuating exchange rate (currently approx. USD 1.35).  
 FOB Project site PA,  
 Packing and Crating for sea freight included,  
 Freight, Insurance, Importation into the USA incl.  
 Delivery time: approx. (11) months

**HYDROPOWER TURBINE SYSTEMS, INC.  
 (HTS-INC)**



## Efficiency





**Figure : Efficiency Curve of an OSSBERGER Turbine with divided guide vanes (Ratio 1:2), without draft tube.**

### OSSBERGER Turbine Efficiency:

Water Flow:	15	30	60	90	100	%
Efficiency:	86	87	87	87	87	%



▽ Rated upper water level



- ① OSSBERGER Turbine  
Type: SH 1.285/20g
- ② Base frame
- ③ Governor (hydraulic)
- ④ Governor (electric)
- ⑤ Reducer/Draft tube
- ⑦ Gearbox with couplings
- ⑨ Generator
- ⑩ Oil cooler
- ⑪ Iron stud

SAMPLE



OSSBERGER GmbH + Co  
P.O. Box 425  
D-91773 WEISSENBURG/BAY

ON-1570  
cad

Project: ERGA - de Cosmo

Scale : 1:50

## **Appendix D: Kaplan Turbine Information**



**Pennsylvania (Machine 2)**


Vertical Axial Flow Turbine (Double Regulated)

900mm / 514 rpm

Hnet = 6.4 m

Canadian Hydro Components





**CANADIAN  
HYDRO  
COMPONENTS LTD.**

16 Main Street-Box 640  
Almonte, ON K0A 1A0  
Canada

Tel: (613) 256-1983

Fax: (613) 256-4235

Email: [inquiries@canadianhydro.com](mailto:inquiries@canadianhydro.com)

[www.canadianhydro.com](http://www.canadianhydro.com)

**BUDGET PRICE**

**DATE: Octoer 29, 2010**

**BP #2010-036 Rev**

**TURBINE DATA**

Pennsylvania Mine Discharge Hydro Project

Project Name	Option 1	Option 2	Option 3
Rated Net Head	6.4 m	6.4 m	6.4 m
Turbine Type	Vertical Axial Flow, DR	Vertical AF, DR	Vertical AF, DR
Runner Diameter	1250 mm	1000 mm	900 mm
Flow/Unit max	8.9 cms	5.8 cms	4.7 cms
Turbine Speed	360 rpm	450 rpm	514 rpm
Generator Speed	360 rpm	450 rpm	514 rpm
Turbine Shaft Output/unit	476 kW	321 kW	260 kW
Generator Output/unit	452 kW	305 kW	247 kW
Turbine Setting	1.0 m below TWL	At TWL	At TWL
Number of Units	1	1	1
Total Output	452 kW	305 kW	247 kW

**EACH EQUIPMENT PACKAGE INCLUDES**

- 1-Runner/Distributor Assembly (Turbine heart and shaft)
- 1-Draft Tube Liner
- 1-Turbine Inlet
- 1-Generator (Induction)
- 1-Hydraulic Power Unit
- 1-Switchgear/Control/Protection

**TOTAL ABOVE W2W PRICE:**

- Option 1 – 1250 mm \$ 1,250,000 USD
- Option 2 – 1000 mm \$ 890,000 USD
- Option 3 – 900 mm \$ 680,000 USD

**PAYMENT SCHEDULE**

Deposit	25 % with order
Progress Payment Due Mid-Contract	45 %
Due Before Shipment	20 %
At successful start-up No later than 120 days after shipment	10 %

GOOD FOR 90 DAYS

ALL PRICES QUOTED IN USD DOLLARS

FOB ALMONTE, ONTARIO

SHIPPING AND CUSTOMS BROKERAGE EXTRA.

**THIS BUDGET PRICE IS FOR ESTIMATING PURPOSES ONLY**

## Appendix E: Tabular Flow Duration Curve

Jeddo Discharge 1997 Measured Data	
Flow (Cubic meters per min)	Probability of Exceedence
15	99.999
30	99.999
45	99.999
60	95.354
75	80.053
90	70.49
105	51.911
120	42.075
135	36.064
150	28.687
165	24.862
180	21.857
195	19.944
210	17.485
225	15.846
240	14.753
255	13.387

570	1.092
585	1.092
600	1.092
615	1.092
630	1.092
645	1.092
660	1.092
675	0.819
690	0.546
705	0.273
720	0.273
735	0.273
750	0.273
765	0
780	0
795	0
810	0

270	12.294
285	10.381
300	9.561
315	8.468
330	7.648
345	6.282
360	5.736
375	5.736
390	4.643
405	4.37
420	4.097
435	3.277
450	2.731
465	2.731
480	2.458
495	2.185
510	2.185
525	1.912
540	1.092
555	1.092



## Appendix F: Project Cost Sheet

Table F- 1: Kaplan Hydroelectric Project Costs

Jeddo Hydroelectric Project Costs		
<b>Feasibility study</b>		
	Site investigation and survey	\$10,000
	Environmental assessment	\$50,000
	Preliminary design	\$30,000
	Detailed cost estimate	\$20,000
	Project management	\$20,000
<b>Development</b>		
	Contract negotiations	\$5,000
	Permits & approvals	\$5,000
	Land rights	inc O&M
	Legal & accounting	\$10,000
<b>Engineering</b>		
	Site & building design	inc
	Mechanical design	inc
	Electrical design	\$50,000
	Civil design	\$292,993
	Construction supervision	inc
<b>Power system</b>		
	Hydro turbine	\$680,000
	Road construction	inc
	Transmission line	\$40,000
	PMT and recloser	\$30,000
<b>Balance of system &amp; miscellaneous</b>		
	Clearing	inc
	Earth excavation	inc
	Rock excavation	inc
	Earthfill dam	inc
	Dewatering	inc
	Spillway	inc
	Intake	inc
	Tunnel	inc
	Penstock	inc
	Powerhouse civil	inc
	BOP dam proposal	\$686,240
	Building & yard construction	inc
	Spare parts	\$50,000
	Transportation turbine, pmt, etc	\$25,000
	Training & turbine commissioning	\$10,000
	<b>Total</b>	<b>\$2,014,233</b>

**Table F- 2: Crossflow Hydroelectric Project Costs**

**Jeddo Hydroelectric Project Costs**


<b>Feasibility study</b>		
	Site investigation and survey	\$10,000
	Environmental assessment	\$50,000
	Preliminary design	\$30,000
	Detailed cost estimate	\$20,000
	Project management	\$20,000
<b>Development</b>		
	Contract negotiations	\$5,000
	Permits & approvals	\$5,000
	Land rights	inc O&M
	Legal & accounting	\$10,000
<b>Engineering</b>		
	Site & building design	inc
	Mechanical design	inc
	Electrical design	\$50,000
	Civil design	\$292,993
	Construction supervision	inc
<b>Power system</b>		
	Hydro turbine	\$ 729,283
	Road construction	inc
	Transmission line	\$40,000
	PMT and recloser	\$30,000
<b>Balance of system &amp; miscellaneous</b>		
	Clearing	inc
	Earth excavation	inc
	Rock excavation	inc
	Earthfill dam	inc
	Dewatering	inc
	Spillway	inc
	Intake	inc
	Tunnel	inc
	Penstock	inc
	Powerhouse civil	inc
	BOP dam proposal	\$686,240
	Building & yard construction	inc
	Spare parts	\$50,000
	Transportation turbine, pmt, etc	\$25,000
	Training & turbine commissioning	\$10,000
	<b>Total</b>	<b>\$2,063,516</b>

# Appendix G: RETScreen Results

The results below are for the Kaplan turbine cost data and energy production estimates assuming the 30% cash grant can be achieved.

## RETScreen Financial Analysis - Power project

Financial parameters			Project costs and savings/income summary				Yearly cash flows			
General			Initial costs				Year	Pre-tax	After-tax	Cumulative
						#	\$	\$	\$	
Fuel cost escalation rate	%		Power system				0	-281,960	-281,960	-281,960
Inflation rate	%	1.2%	100.0%	\$	1,409,800	1	206	206	-281,754	
Discount rate	%	3.0%	Balance of system & misc.				2	1,180	1,180	-280,575
Project life	yr	50	0.0%	\$	0	3	2,165	2,165	-278,410	
<b>Finance</b>			<b>Total initial costs</b>	<b>100.0%</b>	<b>\$ 1,409,800</b>	4	3,162	3,162	-275,247	
Incentives and grants	\$	0	<b>Annual costs and debt payments</b>				5	4,171	4,171	-271,076
Debt ratio	%	80.0%	O&M	\$	35,000	6	5,192	5,192	-265,884	
Debt	\$	1,127,840	Fuel cost - proposed case	\$	0	7	6,225	6,225	-259,658	
Equity	\$	281,960	Debt payments - 30 yrs	\$	81,936	8	7,271	7,271	-252,388	
Debt interest rate	%	6.00%	<b>Total annual costs</b>	<b>\$</b>	<b>116,936</b>	9	8,328	8,328	-244,059	
Debt term	yr	30	<b>Periodic costs (credits)</b>				10	9,399	9,399	-234,661
Debt payments	\$/yr	81,936					11	10,482	10,482	-224,179
<b>Income tax analysis</b>							12	11,577	11,577	-212,602
							13	12,686	12,686	-199,916
							14	13,808	13,808	-186,107
							15	14,943	14,943	-171,164
							16	16,092	16,092	-155,072
							17	17,254	17,254	-137,818
							18	18,430	18,430	-119,388
							19	19,620	19,620	-99,767
							20	20,825	20,825	-78,943
							21	22,043	22,043	-56,900
							22	23,276	23,276	-33,624
							23	24,523	24,523	-9,101
							24	25,786	25,786	16,685
							25	27,063	27,063	43,747
							26	28,355	28,355	72,103
							27	29,663	29,663	101,765
							28	30,986	30,986	132,751
							29	32,325	32,325	165,076
							30	33,680	33,680	198,756
							31	116,987	116,987	315,743
							32	118,374	118,374	434,117
							33	119,777	119,777	553,894
							34	121,198	121,198	675,092
							35	122,635	122,635	797,726
							36	124,089	124,089	921,815
							37	125,560	125,560	1,047,375
							38	127,049	127,049	1,174,424
							39	128,555	128,555	1,302,979
							40	130,079	130,079	1,433,058
							41	131,622	131,622	1,564,679
							42	133,182	133,182	1,697,861
							43	134,761	134,761	1,832,623
							44	136,359	136,359	1,968,982
							45	137,976	137,976	2,106,957
							46	139,612	139,612	2,246,569
							47	141,267	141,267	2,387,836
							48	142,942	142,942	2,530,778
							49	144,637	144,637	2,675,415
							50	146,352	146,352	2,821,767
<b>Annual income</b>			<b>Financial viability</b>							
<b>Electricity export income</b>			Pre-tax IRR - equity				%			
Electricity exported to grid	MWh	1,162	Pre-tax IRR - assets				%			
Electricity export rate	\$/MWh	100.00	After-tax IRR - equity				%			
Electricity export income	\$	116,180	After-tax IRR - assets				%			
Electricity export escalation rate	%	1.2%	Simple payback				yr			
<b>GHG reduction income</b>			Equity payback				yr			
			Net Present Value (NPV)				\$			
Net GHG reduction	tCO2/yr	228	Annual life cycle savings				\$/yr			
Net GHG reduction - 50 yrs	tCO2	11,403	Benefit-Cost (B-C) ratio				3.76			
<b>Customer premium income (rebate)</b>			Debt service coverage				1.00			
			Energy production cost				\$/MWh			
			GHG reduction cost				\$/tCO2			
<b>Other income (cost)</b>										
<b>Clean Energy (CE) production income</b>										



The results below are for the Kaplan turbine cost data and energy production estimates assuming the 30% cash grand CANNOT be utilized.

**RETScreen Financial Analysis - Power project**

Financial parameters			
General			
Fuel cost escalation rate	%		
Inflation rate	%	1.2%	
Discount rate	%	3.0%	
Project life	yr	50	

Finance			
Incentives and grants	\$	0	
Debt ratio	%	80.0%	
Debt	\$	1,611,386	
Equity	\$	402,847	
Debt interest rate	%	6.00%	
Debt term	yr	30	
Debt payments	\$/yr	117,065	

Income tax analysis

Annual income			
Electricity export income			
Electricity exported to grid	MWh	1,289	
Electricity export rate	\$/MWh	100.00	
Electricity export income	\$	128,882	
Electricity export escalation rate	%	1.2%	

GHG reduction income			
Net GHG reduction	tCO2/yr	253	
Net GHG reduction - 50 yrs	tCO2	12,650	

Customer premium income (rebate)

Clean Energy (CE) production income

Project costs and savings/income summary			
Initial costs			
Power system	100.0%	\$	2,014,233
Balance of system & misc.	0.0%	\$	0
<b>Total initial costs</b>	<b>100.0%</b>	<b>\$</b>	<b>2,014,233</b>


Annual costs and debt payments			
O&M		\$	35,000
Fuel cost - proposed case		\$	0
Debt payments - 30 yrs		\$	117,065
<b>Total annual costs</b>		<b>\$</b>	<b>152,065</b>

Periodic costs (credits)

Annual savings and income			
Fuel cost - base case		\$	0
Electricity export income		\$	128,882
<b>Total annual savings and income</b>		<b>\$</b>	<b>128,882</b>

Financial viability			
Pre-tax IRR - equity	%	4.4%	
Pre-tax IRR - assets	%	0.9%	
After-tax IRR - equity	%	4.4%	
After-tax IRR - assets	%	0.9%	
Simple payback	yr	21.5	
Equity payback	yr	33.7	
Net Present Value (NPV)	\$	385,671	
Annual life cycle savings	\$/yr	14,989	
Benefit-Cost (B-C) ratio		1.96	
Debt service coverage		0.81	
Energy production cost	\$/MWh	90.90	
GHG reduction cost	\$/tCO2	(59)	

Yearly cash flows				
Year	Pre-tax	After-tax	Cumulative	
#	\$	\$	\$	\$
0	-402,847	-402,847	-402,847	
1	-22,070	-22,070	-424,917	
2	-20,943	-20,943	-445,860	
3	-19,803	-19,803	-465,663	
4	-18,649	-18,649	-484,313	
5	-17,482	-17,482	-501,795	
6	-16,301	-16,301	-518,095	
7	-15,105	-15,105	-533,200	
8	-13,896	-13,896	-547,096	
9	-12,672	-12,672	-559,768	
10	-11,433	-11,433	-571,201	
11	-10,180	-10,180	-581,381	
12	-8,912	-8,912	-590,294	
13	-7,629	-7,629	-597,923	
14	-6,331	-6,331	-604,254	
15	-5,018	-5,018	-609,272	
16	-3,688	-3,688	-612,960	
17	-2,343	-2,343	-615,304	
18	-983	-983	-616,286	
19	395	395	-615,892	
20	1,788	1,788	-614,104	
21	3,198	3,198	-610,906	
22	4,624	4,624	-606,281	
23	6,068	6,068	-600,213	
24	7,529	7,529	-592,685	
25	9,007	9,007	-583,678	
26	10,502	10,502	-573,176	
27	12,016	12,016	-561,160	
28	13,547	13,547	-547,613	
29	15,096	15,096	-532,517	
30	16,664	16,664	-515,853	
31	18,251	18,251	-497,602	
32	19,858	19,858	-477,744	
33	21,484	21,484	-456,260	
34	23,129	23,129	-433,131	
35	24,793	24,793	-408,338	
36	26,476	26,476	-381,862	
37	28,178	28,178	-353,684	
38	29,899	29,899	-323,785	
39	31,638	31,638	-292,147	
40	33,395	33,395	-258,752	
41	35,169	35,169	-223,583	
42	36,960	36,960	-186,623	
43	38,768	38,768	-147,855	
44	40,593	40,593	-107,262	
45	42,434	42,434	-64,828	
46	44,291	44,291	-20,537	
47	46,163	46,163	19,706	
48	48,050	48,050	67,756	
49	50,000	50,000	117,756	
50	52,000	52,000	169,756	



## Appendix H: Geothermal Primer for Water Source Applications

If a water source is available, it should be evaluated as an option as it can enhance the performance of a system in several ways. Water has a considerably higher heat capacity, at  $4.186 \text{ Kj/Kg}^\circ\text{C}$ <sup>47</sup>, than any of the soil types shown in the Soil Types table so it can store heat and transfer it better than the soils. Water's heat capacity is higher than granite's. Though some of water's other properties are lower than those of the various soil types, water's high heat capacity make it a useful ground loop thermal source. Also, in water source systems, after the water has completed its thermal exchange in the building, it is returned to the water source and all of its heat is removed, not just the partial heat removal that occurs through a heat exchanger in the ground source systems. It should be noted that the process of obtaining the necessary permits to use a nearby pond or river as the water source for a GHP can be challenging. Concerns over both thermal pollution (dumping water into the source at temperatures different than the source) and the potential for leaking an undesirable heat transfer fluid (i.e., propylene glycol or other) into the environment are among the major concerns with water source systems.

The map below illustrates the rather steady groundwater temperature zones across wide swaths of the U.S.




Figure H-1 Average temperature ( $^\circ\text{C}$ ) near the surface of the U.S. from groundwater measurements.<sup>48</sup>

A water-source closed loop system can be employed in a variety of climates providing the water source has enough depth to provide year-round temperatures above freezing. A typical thermal pattern for lakes in the winter has the coldest water (or ice) near the surface while the water near the bottom is around  $39^\circ\text{F}$  the temperature at which maximum density for water occurs.<sup>49</sup> Propylene glycol is commonly used as the heat exchange medium in these systems as it also an effective anti-freeze.

<sup>47</sup> <http://www.engineeringtoolbox.com/> Other water properties: Water's thermal conductivity is  $0.58 \text{ W/m}^\circ\text{C}$ , thermal diffusivity is  $1.39 \times 10^{-4} \text{ m}^2/\text{s}$ , and density is  $1.0 \text{ Kg/m}^3$ .

<sup>48</sup> <http://www.smu.edu/geothermal/heatflow/heatflow.htm> reproduction of the Map by T.E. Gass, in Geothermal Heat Pumps Geothermal Resources Council Bulletin 11(11), 3-8, 1982.

<sup>49</sup> <http://geoheat.oit.edu/otl/otl02-01.pdf>. Outside the Loop - A Newsletter for Geothermal Heat Pump Designers and Installers. Winter 1999 – Volume 2, Number 1.

## Open Loop Systems

Open loop GHP systems require an open body of water such as a lake or stream. The water itself is the heat source or sink. In general, these systems are restricted to warmer climates as the heat pump and heat exchange equipment will not work effectively when water temperatures drop below 45°F (7°C). The exception being buildings in cooler climates with year round cooling needs due to high internal gains.

The characteristics of the water source has a lot of system design implications, so a detailed temperature profile with seasonal variations should be developed or obtained from existing sources (state or federal geological surveys may have appropriate temperature information).<sup>50</sup> Deeper lakes may be thermally stratified so cooler temperature water may be available 30-50 ft (9-15m) below the surface on a nearly year-round basis.

A minimum depth of 10 ft (3 m) is recommended. This depth should be measured at the lowest seasonal level. The maximum recommended capacity is 20 tons per acre (8 tons per hectare) in a cooling dominated climate and 10 tons per acre (4 tons per hectare) in a heating dominated climate.<sup>51</sup>




Figure H-2 Open loop lake system at left; open loop system with river or water well at right.  
Source: John Shonder, Oak Ridge National Laboratory.

Two aspects of using a nearby water source should be considered in detail before the design stage. One is the likelihood of obtaining the necessary permits to both use and to discharge water from a surface or underground source. Discharge of water from an open loop system to a surface water body, such as a stream, may require a National Pollutant Discharge Elimination System (NPDES) permit.<sup>52</sup>

The other is in regards to the water quality itself. Hard water or water prone to scaling due to calcium or magnesium salts content will reduce the heat exchanger effectiveness over time.<sup>53</sup> Other water source issues, such as fouling or filtration, can be readily addressed using solutions developed by the power generation and process industries, which have used rivers and lakes extensively over the years.

<sup>50</sup> <http://geoheat.oit.edu/otl/otl02-01.pdf>. Outside the Loop - Winter 1999 – Volume 2, Number 1.

<sup>51</sup> Ibid. <http://geoheat.oit.edu/otl/otl02-01.pdf>.

<sup>52</sup> [http://www.co.berks.pa.us/douglass/lib/douglass/dep/ground\\_source\\_heat\\_pumps.pdf](http://www.co.berks.pa.us/douglass/lib/douglass/dep/ground_source_heat_pumps.pdf). Commonwealth of Pennsylvania, Ground Source Heat Pump Systems Fact Sheet.

<sup>53</sup> <http://geoheat.oit.edu/bulletin/bull21-1/bull21-1-all.pdf>. SCALING IN GEOTHERMAL HEAT PUMP SYSTEMS, Raferty, Kevin.




## Heat Pumps

The heat pump itself is a critical piece of equipment in GSHP systems. The use of heat pumps in the GSHP systems is what allows the system to effectively take advantage of the heating or cooling provided by the earth.

Heat pumps operate in a very efficient manner as they are not generating heat per se, they are merely moving it. It takes a lot less energy to move heat than to generate it. A comparison of how much energy a system delivers compared to how much it consumes helps to illustrate why the energy savings can be so great in these systems compared to conventional HVAC systems. The efficiency of heating equipment is often measured by its Coefficient of Performance (COP). The COP is a ratio of how much energy a system delivers relative to what it consumes in the process. It is defined, more specifically, as the heating capacity (in Btu/hour) of the heating unit divided by its electrical input (also in Btu/h) at standard (ARI/ISO 13256-1) conditions of 32°F (0°C) entering water for closed loop models and 50°F (10°C) entering water.<sup>54</sup>

Some average COP values for heating equipment are<sup>55</sup>:

- Advanced water to air heat pump 4.0
- Water to air heat pump 3.0
- Air to air heat pump 2.0
- Electric resistance 1.0
- Natural gas furnace 0.75
- Coal furnace 0.70



The schematic at left illustrates the major components of a heat pump. The water-to-refrigerant coil exchanges heat with the ground loop.

Figure H-3 Typical geothermal heat pump configuration  
Source: John Shonder, Oak Ridge National Laboratory.

<sup>54</sup> <http://www.ornl.gov/sci/femp/pdfs/gshp-pro-chal.pdf>. *How to Buy an Energy Efficient Ground Source Heat Pump*. FEMP, Department of Energy.

<sup>55</sup> <http://www.millersvilleborough.org/planning/cwp/view.asp?A=2&Q=268208>. APPENDIX 1: IGSHPA CLOSED-LOOP/GEOHERMAL HEAT PUMP SYSTEMS - DESIGN AND INSTALLATION STANDARDS. Lancaster County Planning Commission.

The graph below illustrates how the entering water temperature (from the earth) impacts the GHP performance relative to its capacity, which in turn affects its ability to meet the load. The steady temperatures provided by the earth enable the heat pumps to operate near peak capacity in both heating and cooling modes. An air-source heat pump, which relies on ambient air for a large part of its thermal energy, can operate at low heating capacities when the outside air is below 50°F (10°C) and at low cooling capacities when outside air is above 80°F (27°C).




Figure H-4 Capacity of a typical 4-ton GHP vs. EWT  
 Source: John Shonder, Oak Ridge National Laboratory

In the graph below, the impact of entering water temperature on the Heating Coefficient of Performance (COP) and Cooling Energy Efficiency Ratio (EER) can be readily seen. Again, the steady earth temperatures enable a GHP to operate near both peak Heating COP and peak Cooling EER which results in more BTU's of heating or tons of cooling delivered per kWh consumed.




Figure H-4 Efficiency of a typical 4-ton GHP as a function of EWT.  
 Source: John Shonder, Oak Ridge National Laboratory.

# Appendix I: Geothermal Heat Pump RETScreen Model Results

	Unit	Climate data	Project
		location	location
Latitude	°N	41.3	41.3
Longitude	°E	-75.7	-75.7
Elevation	m	293	293
Heating design temperature	°C	-13.2	
Cooling design temperature	°C	30.0	
Earth temperature amplitude	°C	20.9	

Month	Air temperature	Relative humidity	Daily solar radiation - horizontal	Atmospheric pressure	Wind speed	Earth temperature	Heating degree-days	Cooling degree-days
	°C	%	kWh/m²/d	kPa	m/s	°C	°C-d	°C-d
January	-2.9	68.3%	1.76	98.3	3.7	-5.5	648	0
February	-1.3	63.4%	2.54	98.3	3.7	-3.6	540	0
March	2.9	61.6%	3.56	98.2	4.0	1.3	468	0
April	9.3	60.4%	4.61	98.1	3.8	8.4	261	0
May	15.1	65.9%	5.39	98.2	3.4	14.9	90	158
June	19.7	71.0%	5.96	98.2	3.1	20.1	0	291
July	22.1	71.5%	5.88	98.3	2.9	22.3	0	375
August	21.1	73.3%	5.18	98.4	2.7	21.1	0	344
September	16.9	75.6%	4.07	98.5	2.9	16.7	33	207
October	10.7	72.3%	2.92	98.5	3.1	9.8	226	22
November	5.6	69.6%	1.77	98.3	3.5	3.7	372	0
December	-0.2	68.8%	1.43	98.3	3.6	-2.4	564	0
<b>Annual</b>	<b>10.0</b>	<b>68.5%</b>	<b>3.76</b>	<b>98.3</b>	<b>3.4</b>	<b>9.0</b>	<b>3,203</b>	<b>1,397</b>
Measured at	m				10.0	0.0		

## Emission Analysis

Base case electricity system (Baseline)		GHG emission factor (excl. T&D)	T&D losses	GHG emission factor
Country - region	Fuel type	tCO2/MWh	%	tCO2/MWh
United States of America	All types	0.544	0.0%	0.544

GHG emission	
Base case	tCO2 43.3
Proposed case	tCO2 96.6
<b>Gross annual GHG emission reduction</b>	tCO2 -53.3
GHG credits transaction fee	% 0.0%
<b>Net annual GHG emission reduction</b>	tCO2 -53.3

is equivalent to -9.8 Cars & light trucks not used

GHG reduction income	
GHG reduction credit rate	\$/tCO2 0.00

## Financial Analysis

Financial parameters		
Inflation rate	%	1.2%
Project life	yr	50
Debt ratio	%	0%

Initial costs		
Heating system	\$	0
Cooling system	\$	0
Other	\$	250,000
<b>Total initial costs</b>	\$	250,000

Incentives and grants		
	\$	0
		0.0%

Annual costs and debt payments		
O&M (savings) costs	\$	2,000
Fuel cost - proposed case	\$	18
<b>Total annual costs</b>	\$	2,018

Annual savings and income		
Fuel cost - base case	\$	12,476
<b>Total annual savings and income</b>	\$	12,476

Financial viability		
Pre-tax IRR - assets	%	4.6%
Simple payback	yr	23.9
Equity payback	yr	20.9

